

Title: **Disclosure of OZWx72 Web Services (API)**

The OZW web server supports a Web Application Programming Interface API. This document describes how this API needs to be used. Different services are supported which are explained herein.

History

Rev	Date	Content
9	27-Nov-2017	Extended description of Portal Web API session timeout
8	05-Sept-2017	Description for test page added
7	05-July-2017	New device variant OCI670 added Remark due to line ending for eca and trend download service Portal Web API service "listextended" added (OZWx72.xx, V07.00)
6	11-Jan-2016	New menu tree services for datapoints New application example for OZW Web API New application example for Portal and OZW Web API (OZWx72.xx, V06.00)
5	4-Nov-2014	Portal Use Cases and Portal Web API added (OZWx72.xx, V05.20)
4	13-May-2013	KNX scheduler- and -calendar write, and ECA- and trending file download added
3	4-Dec-2012	Use cases for integration added New API version supported by OZW772.xx
2	17-July-2012	Expansion in Service "menutree\list" Explanations to "write_datapoint" New Api Version 1.1.0 with enumeration value tag
1	20-March-2012	Initial

Copyright

This documentation is subject to copyright, © Siemens Schweiz AG, Building Technologies Division, 2013-2017.

All rights reserved. The reuse of this documentation in any other document or any other way as a whole or of parts thereof is subject to prior written approval of Siemens Schweiz AG.

The use of the Siemens brand and any associated logos and symbols in the software implementing this interface is prohibited unless prior written approval of Siemens Schweiz AG is granted.

Disclaimer

Changes are possible without prior notice. Revision will not necessarily be increase for transition to released status.

SIEMENS NOR ANY OF THEIR LICENSORS MAKE ANY REPRESENTATIONS OR WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OR THAT THE DOCUMENTATION WILL NOT INFRINGE ANY THIRD PARTY PATENTS, COPYRIGHTS, TRADEMARKS OR OTHER RIGHTS.

THERE IS NO WARRANTY BY SIEMENS OR BY ANY OTHER PARTY THAT THE FUNCTIONS CONTAINED IN THE DOCUMENTATION WILL MEET THE REQUIREMENTS OF THE USER OF THIS DOCUMENTS OR THAT THE DOCUMENTATION WILL BE ERROR-FREE. NO ORAL OR WRITTEN INFORMATION OR ADVICE GIVEN BY A SIEMENS REPRESENTATIVE SHALL CREATE A WARRANTY OR IN ANY WAY AFFECT THIS DISCLAIMER. **YOU ASSUME ALL RESPONSIBILITY TO ACHIEVE YOUR INTENDED RESULTS AND FOR THE INSTALLATION, USE, AND RESULTS OBTAINED FROM IT.**

Content

1. Use Cases on integration via OZW Web API.....	5
1.1 Description of use case	5
1.2 Check Web API version.....	5
1.3 Query plant fault state	5
1.4 Query plant energy indication state.....	5
1.5 Read a device data point.....	6
1.5.1 Variant: Indirect access via the menu tree	6
1.5.2 Variant: Direct access	6
1.6 Write a device data point.....	6
1.6.1 Variant: Indirect access via the menu tree	6
1.6.2 Variant: Direct access	7
2. OZW Web API.....	8
2.1 General.....	8
2.1.1 HTTP response format.....	9
2.1.2 Interface version /api/.....	9
2.1.3 Result	10
2.1.4 User administration	11
2.1.5 Test page for API calls	12
2.1.6 Overview of web services.....	13
2.2 API interface versions	14
2.2.1 API Version 1.0.0	14
2.2.2 API Version 1.1.0	14
2.2.3 API Version 1.2.0	14
2.2.4 API Version 1.3.0	14
2.3 Common services	15
2.3.1 version - /api/version	15
2.4 Authentication services.....	15
2.4.1 version - /api/auth/version	15
2.4.2 login - /api/auth/login	15
2.4.3 logout - /api/auth/logout.....	16
2.5 (Local) Device Services.....	17
2.5.1 version - /api/device/version	17
2.5.2 info - /api/device/info	17
2.6 Device list services.....	18
2.6.1 version - /api/devicelist/version.....	18
2.6.2 list - /api/devicelist/list.....	18
2.7 Fault services.....	20
2.7.1 version - /api/fault/version	20
2.7.2 status - /api/fault/status	20
2.7.3 list - /api/fault/list	21
2.7.4 device - /api/fault/device.....	22
2.8 Energy indicator services	24
2.8.1 version - /api/energyindicator/version	24
2.8.2 status - /api/energyindicator/status	24
2.8.3 list - /api/energyindicator/list	25
2.9 Menu tree services.....	27
2.9.1 Data types	27
2.9.2 version - /api/menutree/version	28
2.9.3 device_root - /api/menutree/device_root.....	28
2.9.4 list - /api/menutree/list	28
2.9.5 read_datapoint - /api/menutree/read_datapoint	33
2.9.6 read_datapoint_direct - /api/menutree/read_datapoint_direct.....	34
2.9.7 datapoint_desc - /api/menutree/datapoint_desc.....	34
2.9.8 datapoint_desc_direct - /api/menutree/datapoint_desc_direct.....	59
2.9.9 write_datapoint - /api/menutree/write_datapoint.....	60
2.9.10 write_datapoint_direct - /api/menutree/write_datapoint_direct.....	66
2.10 Energy cost allocator services.....	68

2.10.1	version - /api/eca/version.....	68
2.10.2	download - /api/eca/download	68
2.11	Trend services	70
2.11.1	version - /api/trend/version	70
2.11.2	download - /api/trend/download	70
3.	Application example for OZW Web API.....	73
3.1	Authentication: login to OZW	73
3.2	Device list: read list	73
3.3	Authentication: logout from OZW	73
4.	Use cases for integration via Portal Web API	74
4.1	Description of use case	74
4.2	Portal Web API: Check version.....	74
4.3	Portal Web API: List of sites	74
4.4	OZW Web API: Availability	74
5.	Portal Web API	75
5.1	General.....	75
5.1.1	HTTP response format.....	75
5.1.2	Interface version /api/...	76
5.1.3	Result	76
5.1.4	User administration	76
5.1.5	Overview of web services.....	77
5.2	API interface versions	77
5.2.1	Portal API version 1.0.2.....	77
5.3	Common services	78
5.3.1	version - /api/version.....	78
5.4	Authentication services.....	78
5.4.1	version - /api/auth/version	78
5.4.2	login - /api/auth/login	78
5.4.3	logout - /api/auth/logout.....	79
5.5	Site services.....	79
5.5.1	version - /api/site/version.....	79
5.5.2	list - /api/site/list.....	80
5.5.3	listextended - /api/site/listextended	81
5.5.4	info - /api/site/info.....	82
6.	Application example for Portal and OZW Web API.....	84
6.1	Authentication: login to Climatix / Synco IC	84
6.2	Site: list of sites	84
6.3	Device list: read list	84
6.4	Authentication: logout from Climatix / Synco IC.....	85

1. Use Cases on integration via OZW Web API

1.1 Description of use case

A central server collect important information from decentralized plants, each equipped with an OZWx72. The information is collected on the server and displayed in the web browser in on an overview page. The page also includes a link to the applicable OZWx72 that allows the operator to go directly to plant operation.

Information to be collected by plant:

- Plant fault state
- Plant energy indication state

Information that is read/write from individual plant devices:

- Read only information from devices, e.g. room temperature actual value
- Read and writeable settings for devices, e.g. room operating mode specification

A web link can be added as a brief introduction on web-based operation of the decentralized plant or OZWx72 with authentication information:

- `https://<ip>/main.app?user=<Username>&pwd=<Password>`
- For example: <https://10.169.10.117/main.app?user=Hauswart&pwd=PMjsuc2r>

1.2 Check Web API version

The service version is used to check whether the OZW Web API version is supported (see Section 2.1.2 in this document).

1.3 Query plant fault state

The service “fault / list” can query the plant’s fault list (see Section 2.7.2 in this document).

- The fault list is empty is the plant has not faults.
- The fault list includes a maximum of 10 of the most important plant faults.
- The first entry on the fault list is the most serious plant fault.

1.4 Query plant energy indication state

The service “energyindicator / list” queries the plant’s energy indicator state (See Sec. 2.8.2).

- There are no setpoint outside the monitored limits if the energy indicator list is empty.
- The energy indicator list includes information for both the entire plant as well as individual devices, how much data is monitored, and how many data points exceed the limits.

1.5 Read a device data point

The “menu tree” services accesses individual devices and their data points (see 2.9).

The following two ID features are required for access

- Unique device serial number, e.g. 00FD00FF01F0
- Specific data point attributes "Address" and "DpSubKey" from the disclosure documentation, e.g. 0x2DFE1001 and 0 (See Sec. 2.9)

1.5.1 Variant: Indirect access via the menu tree

The data point is accessed via the menu tree based on the following workflow

- The service “menu tree/device_root” can determine the device-specific entry point in the menu tree (See Sec. 2.9.3)
 - Parameter: Device serial number and submenu tree “Web” or “Mobile”
 - Result: Menu tree “Id” of the device-specific entry point
- The service “menutree / list” must traverse the menu tree (“MenuItems”) hierarchically up to the data point (“DatapointItems”) until the searched for data point attributes is found (See Sec. 2.9.4)
 - Parameter: Menu tree “Id” (device-specific entry point, hierarchy in menu tree)
 - Result: Data point menu tree “Id”
- The service “menu tree/read_data point” reads the data point value (See Sec. 2.9.5)
 - Parameter: Data point menu tree “Id”
 - Result: Data point value as string

The menu tree “Id” of a data point is not static can change after generating a device web page. The service “device list / list” can query the generation timestamp per device (“TreeDate” / “TreeTime”) to detect a subsequent generation and act accordingly (See Sec. 2.6.2).

1.5.2 Variant: Direct access

The data point is accessed directly via the service "menutree/read_datapoint_direct" (see Section 2.9.6)

- Parameter: Device serial number, data point attribute "Address" and "DpSubKey"
- Result: Data point value as string

The identification attributes "Address" and "DpSubKey" for data points does not change when generating the device page. Nevertheless, subsequent generation should also be detected (see Section 1.5.1) and handled accordingly (see Section 2.6.2). One possible scenario is to change a device configuration and, with it, available data points.

1.6 Write a device data point

The same ID features are required for access as for “Read device data point” (See Sec. 1.5).

1.6.1 Variant: Indirect access via the menu tree

The data point is accessed based on the following process:

- Identical process as for “Read device data point” until the menu tree “Id” for the data point is found (See Sec. 2.9.9)

- The service “menutree/data_point_desc” read the data point description of change (data type, minimum, maximum, setting step, etc.) (See Sec. 2.9.7).
 - Parameter: Data point menu tree “Id”
 - Result: Data point description of change
- A setting dialog box to specify a new data point can be offered in an external application based on data type-based description of change.
- The service “menutree/write_data_point” describes the data point using a new value (See Sec. 2.9.9).
 - Parameter: Data point menu tree “Id” and new data point value

1.6.2 Variant: Direct access

The data point is accessed based on the following process

- The service “menutree/data_point_desc” read the data point description of change (data type, minimum, maximum, setting step, etc.) (see Section 2.9.8).
 - Parameter: Device serial number, data point attribute "Address" and "DpSubKey"
 - Result: Data point description of change
- A setting dialog box to specify a new data point can be offered in an external application based on data type-based description of change.
- The service “menutree/write_data_point” describes the data point using a new value (See Sec. 2.9.10).
 - Parameter: Device serial number, data point attribute "Address" and "DpSubKey", new data point value

2. OZW Web API

2.1 General

The Application Programming Interface (API) is a lean interface to connect HTTP Clients with internal OZW services. All API functions are accessible via the URL **/api/** and are queried similar to REST via HTTP-GET or POST queries. It must be waited each time after an API function query for the associated response before executing the next query (purely synchronous queries). The entire function query (including parameter name and values) must be URL encoded.

All services are offered encrypted via HTTPS and, as an option, unencrypted via HTTP. We expressly recommend using the encrypted services via HTTPS to transmit data protected against intercepts.

The query can select the desired HTTP response format, similar to the Twitter-API.

Request URI (HTTP GET):
<http://mydevice/api/version.format>


Request examples:

`http://192.168.251.1/api/version.json`

`http://192.168.251.1/api/version.xml`

Possible applications as users of the API or web services may include, e.g. smart phone apps or the application server.

The following schematic illustrates how OZW web services are structured:



For the device type OCI670/109 applies that only via portal forwarded Web API calls are supported (see Sec. 5 and 6). Direct Web API service calls return with an error (see Sec. 2.1.3).

2.1.1 HTTP response format

Responses in JSON

Response HTTP header for JSON

```
Content-Type: application/json; charset=utf-8; Content-Language: de1
```

¹ Corresponds to the (web) language of the authenticated user (see Sec.2.1.4).

Strings are JSON encoded in the responses (reserved JSON characters \, "). The data is based on the JSON data types "string" and "number".

Responses in XML

Response HTTP header for XML

```
Content-Type: application/xml; charset=utf-8; Content-Language: de1
```

¹ Corresponds to the (web) language of the authenticated user (see Sec. 2.1.4).

Response HTTP body for XML

```
<?xml version="1.0" encoding="UTF-8"?>
```

Strings are XML encoded in the responses (reserved XML characters <, >, &, ", '). The data is based on the (XML) data type "string" and "decimal".

2.1.2 Interface version /api/...

One service is offered to query the interface version (e.g. /api/auth/version) for each service group (e.g. authentication) and consolidated for the entire APIR or service groups (Web API). The consolidated interface versions is increased accordingly as soon as the interface version is increased on at least one service group. Modifications that are backward and not backward compatible are recognized based on this version.

The interface version is compiled from the major, minor, and patch number; each separated by a period (<http://semver.org>):

M.N.P	(Major.MiNor.Patch, e.g. 1.4.11)
-------	----------------------------------

The major version of the queried client "must be the same as the interface version" for the application as user to be compatible with the interface. The minor and patch versions may be greater than or equal to the client's.

and	$M_{API} = M_{AppI}$	(same major number)
	$N.P_{API} \geq N.P_{AppI}$	(Minor.Patch must be greater than or equal to)

Major: For extensions that are not backward compatible, the major number is incremented. One example is a change to the number or sequence of method arguments.

Minor: For backward compatible extensions, the minor number is incremented. One example are (option) supplemental or new services.

Patch: For corrections that do not impact the interface, only the patch number is incremented. An example is error corrections. The patch number should be increased for each change, unless the change causes an increment to the major or minor number.

2.1.3 Result

The parameter **Success** provides information on whether a service was correctly executed.

Response body in JSON (Service successful):

```
{
  "Result": {
    "Success": "true"
  }
}
```

Response body in JSON (Service not successful):

```
{
  "Result": {
    "Success": "false",
    "Error": {
      "Txt": "Write failed",
      "Nr": "3"
    }
  }
}
```

Response body in XML (Service successful):

```
<Service>
  <Result>
    <Success>true</Success>
  </Result>
</Service>
```

Response body in XML (Service not successful):

```
<Service>
  <Result>
    <Success>>false</Success>
    <Error>
      <Txt>Write failed</Txt>
      <Nr>3</Nr>
    </Error>
  </Result>
</Service>
```

Table of all possible errors in all service groups and services

Error Number		Error														
		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Error Text		unknown error	unknown user or wrong password	session not valid	serial number not found	tree name not valid	tree id not found	read failed	write failed	data type not supported	value not valid	unknown service	unknown format	Serial number or tree name not found	No trend defined or trend version not supported	local access denied ¹
<ip-addr>/api/																
.../.../	.../version	(X)	-	-	-	-	-	-	-	-	-	-	-	-	-	(X)
.../auth/	.../login	-	X	-	-	-	-	-	-	-	-	-	-	-	-	(X)
	.../logout	-	-	X	-	-	-	-	-	-	-	-	-	-	-	(X)
.../device/	.../info	-	-	X	-	-	-	-	-	-	-	-	-	-	-	(X)
.../devicelist/	.../list	-	-	X	-	-	-	-	-	-	-	-	-	-	-	(X)
.../fault/	.../status	-	-	X	-	-	-	-	-	-	-	-	-	-	-	(X)
	.../list	-	-	X	-	-	-	-	-	-	-	-	-	-	-	(X)
	.../device	-	-	X	X	-	-	-	-	-	-	-	-	-	-	(X)
.../energyindicator/	.../status	-	-	X	-	-	-	-	-	-	-	-	-	-	-	(X)
	.../list	-	-	X	-	-	-	-	-	-	-	-	-	-	-	(X)
.../menutree/	.../device_root	-	-	X	-	X	-	-	-	-	-	-	X	-	-	(X)
	.../list	-	-	X	-	-	X	-	-	-	-	-	-	-	-	(X)
	.../read_datapoint...	-	-	X	-	-	X	X	-	X	-	-	-	-	-	(X)
	.../datapoint_desc...	-	-	X	-	-	X	X	-	X	-	-	-	-	-	(X)
.../trend/	.../write_datapoint...	-	-	X	-	-	X	-	X	X	X	-	-	-	-	(X)
	.../status	-	-	X	-	-	-	-	-	-	-	-	-	-	-	(X)
.../eca/	.../download	-	-	X	-	-	-	-	-	-	-	-	-	X	-	(X)
	.../download	-	-	X	-	-	-	-	-	-	-	-	-	-	-	(X)
.../unknown/	.../.../	-	-	-	-	-	-	-	-	-	X	-	-	-	-	(X)
.../.../	.../unknown	-	-	-	-	-	-	-	-	-	X	-	-	-	-	(X)
.../.../	.../known.unknown	-	-	-	-	-	-	-	-	-	-	X	-	-	-	(X)

¹ For the device type OCI670/109 applies that only via portal forwarded Web API calls are supported (see Sec. 5 and 6). Direct Web API service calls return with an error „local access denied“.

2.1.4 User administration

Web service user administration occurs together with web operation, used as well for administration. The entered web language of the use defines the language of the data queried via web services.

Authentication occurs the first from via the service "login" (see Sec. 2.4.2) and later on other services via the received session ID (e.g. SessionId=de9e76dc-d17a-4735-94f8-4487606f5278). Session administration is separate from web operation. A session is saved non-persistent in OZW and has a relative timeout of 15 minutes for user inactivity and an absolute timeout of 24 hours.

A user is temporarily blocked for security reasons if an incorrect password is entered multiple times for the "login" service.


2.1.5 Test page for API calls

The OZW provides a web page to try out WEB API calls.

To access this hidden page you have to login via web interface either directly to OZW or to Portal. Via Portal you need to open the OZW web page in new browser tab or window. Change the value of the URL parameter “section” to “webapi”.


Examples:

<https://192.168.251.1/...?SessionId=...§ion=popcard> → [...§ion=webapi](https://192.168.251.1/...?SessionId=...§ion=webapi)
<https://www.siemens-syncoic.com/.../...?SessionId=...§ion=popcard> → [...§ion=webapi](https://www.siemens-syncoic.com/.../...?SessionId=...§ion=webapi)



The Web API authentication can be done “Local” with OZW credentials or via “Portal” with portal credentials. Follow strictly the procedure for access via portal explained in tool tips. Due to the same-origin-policy all portal responses will be shown in a separate window.

2.1.6 Overview of web services



2.2 API interface versions

2.2.1 API Version 1.0.0

Service group	API	Interface version	OZW772 as of	OZW672 as of
API	/api/	1.0.0	V04.04	
Authentication	.../auth/	1.0.0	V04.04	
(Local) Device	.../device/	1.0.0	V04.04	
DeviceList	.../devicelist/	1.0.0	V04.04	
Fault	.../fault/	1.0.0	V04.04	
Energy Indicator	.../energyindicator/	1.0.0	V04.04	
Menu tree	.../menutree/	1.0.0	V04.04	

2.2.2 API Version 1.1.0

Service group	API	Interface version	OZW772 as of	OZW672 as of
API	/api/	1.1.0	V04.06	V04.05
Authentication	.../auth/	1.0.0	V04.06	V04.05
(Local) Device	.../device/	1.0.0	V04.06	V04.05
DeviceList	.../devicelist/	1.0.0	V04.06	V04.05
Fault	.../fault/	1.0.0	V04.06	V04.05
Energy Indicator	.../energyindicator/	1.0.0	V04.06	V04.05
Menu tree	.../menutree/	1.1.0	V04.06	V04.05

2.2.3 API Version 1.2.0

Service group	API	Interface version	OZW772 as of	OZW672 as of
API	/api/	1.2.0	V04.06	V04.05
Authentication	.../auth/	1.0.0	V04.06	V04.05
(Local) Device	.../device/	1.0.0	V04.06	V04.05
DeviceList	.../devicelist/	1.0.0	V04.06	V04.05
Fault	.../fault/	1.0.0	V04.06	V04.05
Energy Indicator	.../energyindicator/	1.0.0	V04.06	V04.05
Menu tree	.../menutree/	1.1.0	V04.06	V04.05
Trend	.../trend/	1.0.0	V05.00	V05.00
Eca	.../eca/	1.0.0	V05.00	-

2.2.4 API Version 1.3.0

Servicegruppe	API	Interfaceversion	OZW772 as of	OZW672 as of
API	/api/	1.3.0	V06.00	V06.00
Authentification	.../auth/	1.0.0	V04.06	V04.05
(Local) Device	.../device/	1.1.0	V06.00	V06.00
DeviceList	.../devicelist/	1.0.0	V04.06	V04.05
Fault	.../fault/	1.0.0	V04.06	V04.05
Energy Indicator	.../energyindicator/	1.0.0	V04.06	V04.05
Menutree	.../menutree/	1.2.0	V06.00	V06.00
Trend	.../trend/	1.0.0	V05.00	V05.00
Eca	.../eca/	1.0.0	V05.00	-

2.3 Common services

Function name	Application
version	Version information of all API services

2.3.1 version - /api/version

Request URI (HTTP GET):

<http://mydevice/api/version.format>

Request example:

```
http://192.168.251.1/api/version.json
```

Response body in JSON:

```
{
  "Version": "1.1.9",
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Version>1.1.9</Version>
  <Result>...</Result>
</Service>
```

2.4 Authentication services

Function name	Application
version	Version information of authentication services
login	Authentication and resolving a SessionID
logout	Ending a session

2.4.1 version - /api/auth/version

Request URI (HTTP GET):

<http://mydevice/api/auth/version.format>

Request example:

```
http://192.168.251.1/api/auth/version.json
```

The response content is the same as for service version - /api/version (Sec. 2.3.1).

2.4.2 login - /api/auth/login

Request URI (HTTP GET):

<http://mydevice/api/auth/login.format>

Example:

```
http://192.168.251.1/api/auth/login.json?user=HansMuster&pwd=MyPassword
```

Request parameter:

Parameter	Example	Default value	Description
user	HansMuster	(none)	User name
pwd	MyPassword	(none)	Password

Response body in JSON:

```
{
  "SessionId": "0bc991a1-04eb-4a7c-8371-4ab648ec8a88" ,
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <SessionId>0bc991a1-04eb-4a7c-8371-4ab648ec8a88</SessionId>
  <Result>...</Result>
</Service>
```

2.4.3 logout - /api/auth/logout

Request URI (HTTP GET):

<http://mydevice/api/auth/logout.format>

Request example:

```
http://192.168.251.1/api/auth/logout.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session

Response body in JSON:

```
{
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Result>...</Result>
</Service>
```

2.5 (Local) Device Services

Function name	Application
version	Device services version information
info	General information on the local OZW device

2.5.1 version - /api/device/version

Request URI (HTTP GET):

<http://mydevice/api/device/version.format>

Request example:

```
http://192.168.251.1/api/device/version.json
```

The response content is the same as for service version - /api/version (Sec. 2.3.1).

2.5.2 info - /api/device/info

Request URI (HTTP GET):

<http://mydevice/api/device/info.format>

Request example:

```
http://192.168.251.1/api/device/info.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session

Response body in JSON:

```
{
  "Device": {
    "Name": "My Web control unit",
    "Addr": "0.2.33",
    "Type": "OZW772.16",
    "FabNr": "531",
    "SerialNr": "00FD00FF01F0",
    "FwVersion": "4.1.2",
    "SysDefVersion": "2.11.1"
  }
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Device>
    <Name>My web control unit</Name>
    <Addr>0.2.33</Addr>
    <Type>OZW772.16</Type>
    <FabNr>531</FabNr>
    <SerialNr>00FD00FF01F0</SerialNr>
    <FwVersion>4.1.2</SwVersion>
    <SysDefVersion>2.11.1</SysDefVersion>
  </Device>
  <Result>...</Result>
</Service>
```

2.6 Device list services

Function name	Application
version	Device list services version information
list	List of centralized logged devices for monitoring and operation ¹

¹ The list is not sorted

2.6.1 version - /api/devicelist/version

Request URI (HTTP GET):

<http://mydevice/api/devicelist/version.format>

Request example:

`http://192.168.251.1/api/devicelist/version.json`

The response content is the same as for service version - /api/version (Sec. 2.3.1).

2.6.2 list - /api/devicelist/list

Request URI (HTTP GET):

<http://mydevice/api/devicelist/list.format>

Request example:

`http://192.168.251.1/api/devicelist/list.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88`

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session

Response body in JSON:

```
{
  "Devices": [
    {
      "Name": "My web control unit",
      "Addr": "0.2.150",
      "Type": "OZW772.16",
      "SerialNr"1: "00FD00FF01F0",
      "TreeDate": "23.05.2011",
      "TreeTime": "12:36",
      "TreeGenerated": "true"
    },
    {
      "Name": "My central apartment unit",
      "Addr": "0.2.33",
      "Type": "QAX910",
      "SerialNr"1: "00FD00015C88",
      "TreeDate": "23.05.2011",
      "TreeTime": "12:37",
      "TreeGenerated": "false"
    }
  ],
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Devices>
    <Device>
      <Name>My web control unit</Name>
      <Addr>0.2.150</Addr>
      <Type>OZW772.16</Type>
      <SerialNr>00FD00FF01F0</SerialNr>1
      <TreeDate>23.05.2011</TreeDate>
```

```
                <TreeTime>12:36</TreeTime>
                <TreeGenerated>>true</TreeGenerated>2
            </Device>
            <Device>
                <Name>My central apartment unit</Name>
                <Addr>0.2.33</Addr>
                <Type>QAX910</Type>
                <SerialNr>00FD00015C88</SerialNr>1
                <TreeDate>23.05.2011</TreeDate>
                <TreeTime>12:37</TreeTime>
                <TreeGenerated>>false</TreeGenerated>2
            </Device>
        </Devices>
    </Result>...</Result>
</Service>
```

¹ A device can be uniquely identified based on the parameter “SerialNr”.

² Status as to whether a menu tree is generated for this device.

2.7 Fault services

Function name	Application
version	Fault services version information
status	Plant alarm state
list	List of plant faults ¹
device	Worst fault on a device

¹ List with a maximum of 10 device faults sorted by fault relevance. Per device is maximal one device fault listed.

2.7.1 version - /api/fault/version

Request URI (HTTP GET):

<http://mydevice/api/fault/version.format>

Request example:

```
http://192.168.251.1/api/fault/version.json
```

The response content is the same as for service version - /api/version (Sec. 2.3.1).

2.7.2 status - /api/fault/status

Request URI (HTTP GET):

<http://mydevice/api/fault/status.format>

Request example:

```
http://192.168.251.1/api/fault/status.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session

Response body in JSON (without plant fault):

```
{
  "HasFault": "false",
  "Result": ...
}
```

Response body in JSON (with plant faults):

```
{
  "HasFault": "true",
  "Result": ...
}
```

Response body in XML (without plant fault):

```
<Service>
  <HasFault>>false</HasFault>
  <Result>...</Result>
</Service>
```

Response body in XML (with plant faults):

```
<Service>
  <HasFault>>true</HasFault>
  <Result>...</Result>
</Service>
```

2.7.3 list - /api/fault/list

Request URI (HTTP GET):

<http://mydevice/api/fault/list.format>

Request example:

```
http://192.168.251.1/api/fault/list.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session

Response body in JSON (without plant fault):

```
{
  "Faults":
    [
  ],
  "FaultsText": "Plant OK1"
  "Result": ...
}
```

¹ Text “Plant OK” in the language of the authenticated user.

Response body in JSON (with plant faults):

```
{
  "Faults":
    [
      {
        "Text": "TA sensor fault",
        "Date": "06.04.2011",
        "Time": "14:33",
        "Id": "10"
        "Device":
          {
            "Name": "My central apartment unit",
            "Addr": "0.2.33",
            "Type": "QAX910",
          }
      },
      {
        "Text": "Device failure",
        "Date": "20.04.2011",
        "Time": "18:11",
        "Id": "5012"
        "Device":
          {
            "Name": "My web control unit",
            "Addr": "0.2.150",
            "Type": "OZW772.16",
          }
      }
    ],
  "FaultsText": "Fault1"
  "Result": ...
}
```

¹ Text “Fault” in the language of the authenticated user.

Response body in XML (without plant fault):

```
<Service>
  <Faults>
  </Faults>
  <FaultsText>Plant OK1</FaultsText>
  <Result>...</Result>
</Service>
```

¹ Text “Plant OK” in the language of the authenticated user.

Response body in XML (with plant faults):

```
<Service>
  <Faults>
    <Fault>
      <Text>TA sensor fault</Text>
      <Date>06.04.2011</Date>
      <Time>14:33</Time>
      <Id>10</Id>
      <Device>
        <Name>My central apartment unit</Name>
        <Addr>0.2.33</Addr>
        <Type>QAX910</Type>
      </Device>
    </Fault>
    <Fault>
      <Text>Device failure</Text>
      <Date>20.04.2011</Date>
      <Time>18:11</Time>
      <Id>5012</Id>
      <Device>
        <Name>My web control unit</Name>
        <Addr>0.2.150</Addr>
        <Type>OZW772.16</Type>
      </Device>
    </Fault>
  </Faults>
  <FaultsText>Fault1</FaultsText>
  <Result>...</Result>
</Service>
```

¹ Text "Fault" in the language of the authenticated user.

2.7.4 device - /api/fault/device

Request URI (HTTP GET):

<http://mydevice/api/fault/device.format>

Request example:

```
http://192.168.251.1/api/fault/device.json?sessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88
&SerialNumber=00FD00FF01F0
```

Request parameter:

Parameter	Example	Default value	Description
sessionId	0bc991a1-04eb-4a7c-...	(none)	sessionId of the current session
SerialNumber	00FD00FF01F0	(none)	Unique device serial number

Response body in JSON (without device fault):

```
{
  "Result": ...
}
```

Response body in JSON (with device fault):

```
{
  "Fault": {
    "Text": "TA sensor fault",
    "Date": "06.04.2011",
    "Time": "14:33",
    "Id": "10",
    "Device": {
      "Name": "My central apartment unit",
      "Addr": "0.2.33",
      "Type": "QAX910",
    }
  },
}
```

```
} "Result": ...
```

Response body in XML (without device fault):

```
<Service>  
  <Result>...</Result>  
</Service>
```

Response body in XML (with device fault):

```
<Service>  
  <Fault>  
    <Text>TA sensor fault</Text>  
    <Date>06.04.2011</Date>  
    <Time>14:33</Time>  
    <Id>10</Id>  
    <Device>  
      <Name>My central apartment unit</Name>  
      <Addr>0.2.33</Addr>  
      <Type>QAX910</Type>  
    </Device>  
  </Fault>  
  <Result>...</Result>  
</Service>
```

2.8 Energy indicator services

Function name	Application
version	Energy Indicator Service version info
status	Plant energy indication state
list	List of plant energy indication messages ¹

¹ List of max. 10 energy indication messages sorted by message relevance.

2.8.1 version - /api/energyindicator/version

Request URI (HTTP GET):

<http://mydevice/api/energyindicator/version.format>

Request example:

```
http://192.168.251.1/api/energyindicator/version.json
```

The response content is the same as for service version - /api/version (Sec. 2.3.1).

2.8.2 status - /api/energyindicator/status

Request URI (HTTP GET):

<http://mydevice/api/energyindicator/status.format>

Request example:

```
http://192.168.251.1/api/energyindicator/status.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session

Response body in JSON (Energy Indicator not activated):

```
{
  "IsIndicationActive"1: "false",
  "HasIndication"2: "false",
  "Result": ...
}
```

¹ Status on whether the function energy indicator is active or at least 1 plant data point is being monitored.

² Status as to whether at least one indication message exists.

Response body in JSON (Energy indicator is activated, without energy indication messages):

```
{
  "IsIndicationActive": "true",
  "HasIndication": "false",
  "Result": ...
}
```

Response body in JSON (Energy indicator activated, with energy indication messages):

```
{
  "IsIndicationActive": "true",
  "HasIndication": "true",
  "Result": ...
}
```

Response body in XML (Energy indicator not activated):

```
<Service>
  <IsIndicationActive>>false</IsIndicationActive>1
```

```
<HasIndication>false</HasIndication>2
<Result>...</Result>
</Service>
```

¹ Status whether the function energy indicator is activated.

² Status whether at least one indication message exists.

Response body in XML (Energy indicator activated, without energy indication messages):

```
<Service>
  <IsIndicationActive>true</IsIndicationActive>
  <HasIndication>false</HasIndication>
  <Result>...</Result>
</Service>
```

Response body in XML (Energy indicator activated, with energy indication messages):

```
<Service>
  <IsIndicationActive>true</IsIndicationActive>
  <HasIndication>true</HasIndication>
  <Result>...</Result>
</Service>
```

2.8.3 list - /api/energyindicator/list

Request URI (HTTP GET):

<http://mydevice/api/energyindicator/list.format>

Request example:

```
http://192.168.251.1/api/energyindicator/list.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session

Response body in JSON (without energy indication messages):

```
{
  "Indications":
    [
    ],
  "IndicationsText": "Plant OK1"
  "Result": ...
}
```

¹ Text "Plant OK" in the language of the authenticated user.

Response body in JSON (with energy indication messages):

```
{
  "Indications":
    [
      {
        "Text": "2 setpoints from 5 monitored setpoints ..."
        "Device":
          {
            "Name": "My central apartment unit",
            "Addr": "0.2.33",
            "Type": "QAX910",
          }
      },
      {
        "Text": "2 setpoints from 5 monitored setpoints ..."
        "Device":
          {
            "Name": "My universal controlled",
            "Addr": "0.2.55",
            "Type": "RMU730B",
          }
      }
    ]
}
```

```
    ],  
    "IndicationsText": "5 of 23 monitored setpoints exceed a limit"1  
    "Result": ...  
}
```

¹ Text "x setpoints of y monitored setpoints exceed a limit" in the language of the authenticated user.

Response body in XML (without energy indication messages):

```
<Service>  
  <Indications>  
  </Indications>  
  <IndicationsText>Plant OK1</IndicationsText>  
  <Result>...</Result>  
</Service>
```

¹ Text "Plant OK" in the language of the authenticated user.

Response body in XML (with Energy Indication messages):

```
<Service>  
  <Indications>  
    <Indication>  
      <Text>2 of 5 monitored values have exceeded your green limits...</Text>  
      <Device>  
        <Name>My central apartment unit</Name>  
        <Addr>0.2.33</Addr>  
        <Type>QAX910</Type>  
      </Device>  
    </Indication>  
    <Indication>  
      <Text>2 of 5 monitored values have exceeded your green limits...</Text>  
      <Device>  
        <Name>My universal controller</Name>  
        <Addr>0.2.55</Addr>  
        <Type>RMU730</Type>  
      </Device>  
    </Indication>  
  </Indications>  
  <IndicationsText>5 of 23 monitored values have exceeded your green  
limits...1</IndicationsText>  
  <Result>...</Result>  
</Service>
```

¹ Text "x of y monitored values have exceeded your Green Limits" in the language of the authenticated user.

2.9 Menu tree services

Function name	Application
version	Menu tree services version information
device_root	Query the entry point in the menu tree of a defined device and a defined sub-menu tree (mobile, SMS, etc.)
list	Query the menu and data point item list at a defined location.
	<i>Indirect identification of a data point via the menu tree ID</i>
read_datapoint	Read a data point value
write_datapoint	Write a data point value
datapoint_desc	Data point description of change (minimum, maximum, adjustment step, etc.)
	<i>Direct identification of a data point via device serial number, data point address and SubKey</i>
read_datapoint_direct	Read a data point value
write_datapoint_direct	Write a data point value
datapoint_desc_direct	Data point description of change (minimum, maximum, adjustment step, etc.)

The services “read_datapoint...”, “write_datapoint...” and “datapoint_desc...” can access individual devices and their data points. A data point can be uniquely identified based on parameters “Address” and “DpSubKey”. The two parameters are included in the disclosure document for the applicable device.

The disclosure documents can be order as per the "Non-Disclosure & Confidentiality License Agreement" from regional Siemens representatives.

2.9.1 Data types

An overview of supported data types:

Data type	Application	Data type in internal data model
String	String	LSTRING, NEWSTRING, STRING20, VALMV ¹
Numeric	Numerical values	VALA16/32, VALI32, VALI8/16/32, VALN8/16/32, VALMN8/16/32, VALCNT ¹
Enumeration	Enumerations	VALME8/16
CheckBox	Checkboxes	VALS/S8
RadioButton	Radio buttons	VALB, VALSB8/SB
DateTime	Time & date	VALDATE, VALDAYDATE
TimeOfDay	Time of day (relative)	LVALT, VALTOD_RELATIVE
TimeOfDay	Time of day (absolute)	LVALTOD, VALTOD
Scheduler	Daily scheduler (field bus LPB)	LTSPRG
Scheduler	Daily scheduler (field bus KNX)	SWITCHPOINT
Calendar	Holiday/exception day programs (field bus KNX)	EXCEPTIONPERIODS
AlarmInfo ¹	Alarm information	ALARMINFO ¹

¹ These data types can only be read system-wide. Services write_data point & data point_desc are not supported.

2.9.2 version - /api/menutree/version

Request URI (HTTP GET):

<http://mydevice/api/menutree/version.format>

Request example:

```
http://192.168.251.1/api/menutree/version.json
```

The response content is the same as for service version - /api/version (Sec. 2.3.1).

2.9.3 device_root - /api/menutree/device_root

Request URI (HTTP GET):

http://mydevice/api/menutree/device_root.format

Request example:

```
http://192.168.251.1/api/menutree/device_root.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88
&SerialNumber=00FD00FF01F0&TreeName=Mobile
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session
SerialNumber	00FD00FF01F0	(none)	Unique device serial number
TreeName ¹	Mobile	(none)	Sub-menu tree (Web, Mobile, SMS, ...) ¹ of a device

¹ Currently, only sub-menu trees "Web" (menu tree for web operation) and "Mobile" (optimized device status pages for smartphone Apps) are supported.

Response body in JSON:

```
{
  "TreeItem":
  {
    "Id": "922"
  }
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <TreeItem>
    <Id>922</Id>
  </TreeItem>
  <Result>...</Result>
</Service>
```

2.9.4 list - /api/menutree/list

Request URI (HTTP GET):

<http://mydevice/api/menutree/list.format>

Request example:

```
http://192.168.251.1/api/menutree/list.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88&Id=922
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session
Id	922	(none)	Father menu in the menu tree

Response body in JSON:

```
{
  "MenuItems":
  [
    {
      "Id": 1015,
      "Text" :
      {
        "CatId": "1",
        "GroupId": "4",
        "Id": "134",
        "Long": "Room operating mode",
        "Short": "Room op mode",
      }
    },
  ],
  "DatapointItems":
  [
    {
      "Id": "45",
      "Address": "0x102F1001",
      "DpSubKey": "0",
      "WriteAccess": "true",
      "Text" :
      {
        "CatId": "1",
        "GroupId": "2",
        "Id": "1949",
        "Long": "Overshoot time",
        "Short": "Overshoot time",
      }
    },
    {
      "Id": "1020",
      "Address": "0x102F2001",
      "DpSubKey": "0",
      "WriteAccess": "false",
      "Text" :
      {
        "CatId": "1",
        "GroupId": "2",
        "Id": "319",
        "Long": "Comfort heating setpoint",
        "Short": "Comf. heating setpoint",
      }
    }
  ],
  "WidgetItems":
  [
    {
      "Id": "45",
      "Area": "1",
      "Type": "0",
      "WidgetId": "1",
      "Priority": "2",
      "IconNr": "14",
      "PressedValue": "0",
      "Data point" :
      {
        "Id": "46",
        "GroupTxtId": "542",
      },
      "Text" :
      {
        "CatId": "1",
        "GroupId": "2",
        "Id": "319",
        "Long": "Comfort heating setpoint",
        "Short": "Comf. heating setpoint",
      }
    },
    {
      "Id": "47",
```

```

        "Area": "2",
        "Type": "3",
        "WidgetId": "1",
        "Priority": "2",
        "IconNr": "33",
        "PressedValue": "0",
        "Datapoint" :
        {
            "Id": "48",
            "GroupTxtId"1: "543"
        },
        "DatapointFeedback"4:
        {
            "Id": "49",
            "GroupTxtId"1: "335"
        },
        "Text" :
        {
            "CatId"1: "1",
            "GroupId"1: "2",
            "Id"1: "320",
            "Long": "Comfort heating setpoint",
            "Short": "Comf. heating setpoint",
        }
    }
}

"Result": ...
}

```

- ¹ (Text-) CatId, GroupId and Id result together in a unique reference to a text.
- ² Widget information is only available in the sub-menu tree "Mobile". A widget item represents a data point that is visualized on a smartphone App as widget. The WidgetId is a unique reference within a device menu tree.
- ³ Inside a device can a data point be uniquely identified based on parameters "Address" and "DpSubKey". The two parameters are included in the disclosure document on the device.
- ⁴ Parameters for feedback data point are available even if a corresponding feedback data point is defined.

Response body in XML:

```

<Service>
  <MenuItems>
    <MenuItem>
      <Id>1015</Id>,
      <Text>
        <CatId>1</CatId>
        <GroupId>4</GroupId>
        <Id>134</Id>
        <Long>Room operating mode</Long>
        <Short>Room op mode</Short>
      </Text>
    </MenuItem>
  </MenuItems>
  <DatapointItems>
    <DatapointItem>
      <Id>45</Id>,
      <Address>0x102F1001</Address>
      <DpSubKey>0</DpSubKey>
      <WriteAccess>true</WriteAccess>
      <Text>
        <CatId>1</CatId>
        <GroupId>2</GroupId>
        <Id>1949</Id>
        <Long>Overshoot time</Long>
        <Short>Overshoot time</Short>
      </Text>
    </DatapointItem>
  </DatapointItems>
</Service>

```

```

<Id>1020</Id>
<Address>0x102F2001</Address>
<DpSubKey>0</DpSubKey>
<WriteAccess>>false<WriteAccess>
<Text>
    <CatId>1</CatId>
    <GroupId>2</GroupId>
    <Id>319</Id>
    <Long>Comfort heating setpoint</Long>
    <Short>Comf. heating setp.</Short>
</Text>
</DatapointItem>
<DatapointItems>
<WidgetItems>
    <WidgetItem>
        <Id>45</Id>
        <Area>1</Area>
        <Type>0</Type>
        <WidgetId>1</WidgetId>
        <Priority>2</Priority>
        <IconNr>14</IconNr>
        <PressedValue>0</PressedValue>
        <Datapoint>
            <Id>46</Id>
            <GroupTxtId>542</GroupTxtId>
        </Datapoint>
        <Text>
            <CatId>1</CatId>
            <GroupId>2</GroupId>
            <Id>319</Id>
            <Long>Comfort heating setpoint</Long>
            <Short>Comf. heating setp.</Short>
        </Text>
    </WidgetItem>
    <WidgetItem>
        <Id>47</Id>
        <Area>2</Area>
        <Type>3</Type>
        <WidgetId>2</WidgetId>
        <Priority>1</Priority>
        <IconNr>33</IconNr>
        <PressedValue>0</PressedValue>
        <Datapoint>
            <Id>48</Id>
            <GroupTxtId>543</GroupTxtId>
        </Datapoint>
        <DatapointFeedback>
            <Id>49</Id>
            <GroupTxtId>335</GroupTxtId>
        </DatapointFeedback>
        <Text>
            <CatId>1</CatId>
            <GroupId>2</GroupId>
            <Id>320</Id>
            <Long>PreComfort heating setpoint</Long>
            <Short>PreComf. heating setp.</Short>
        </Text>
    </WidgetItem>
</WidgetItems>
<Result>...</Result>
</Service>

```

Widget item parameters:

Parameter	Example	Description
Id	47	Widget item in the menu tree
Area	0, 1, 2	Display area of the widget item 0 (Status), 1 (Basic), 2 (Work area)
Type	3	Widget item type: 0 (Common), 1 (PushButton), 2 (PushButtonDual), 3 (Range), 4 (List)
WidgetId	2	Unique, static Id within a device
Priority	1	Priority among all a device's widget item. Value "0"

		is reserved for "not defined".
IconNr	33	Icon to widget item
PressedValue	0, 1, ...	<i>Only for widget type "PushButton":</i> Value of activated element
Data point: Id	48	Data point referenced by widget in the menu tree
Data point: GroupTxtId	543	<i>Only for widget type "List", "PushButton" or "PushButtonDual":</i> Text group of values enumeration to referenced data point.
Data point feedback: Id	59	<i>Only for widget type "List":</i> Feedback data point referenced by widget in the menu tree
Data point feedback: GroupTxtId	335	<i>For only widget type "List":</i> Text group of value enumeration to referenced feedback data point
Text: CatId	1	System catalog of widget item text
Text: GroupId	2	Text group of the widget item text
Text: Id	320	TextId of widget item text
Text: Long	PreComfort heating setpoint	Long widget item text
Text: Short	PreComf. heating setp.	Short widget item text

Dialog example of widget items in work area of a smartphone App:

Widget item type	Widget item inactive	Widget item active	Description
1, PushButton	 DHW Push	 Activate	Operation for an event trigger
2, PushButtonDual	 Galerie	 Ein Galerie Aus	Operating for two-event triggers
3, Range	 Raum-Komfortswert 21.0°C	 Raumtemperatur 20.0	Operation for value with setting range
4, List	 Wohnung	 Auto Comfort Pre-Comfort Reduced Protection	Operation with selection list (with feedback data point)
4, List	 Wohnung	 Auto Comfort Pre-Comfort Reduced Protection	Operating with selection list (without feedback data point)

Dialog example for widget item in basic are¹ of a smartphone App:

Widget item type	Display	Description
(2, PushButtonDual) ¹ (3, Range) ¹ (4, List) ¹	Raum 20.3°C	Display for value

¹ In the basic area, widget items are read only and cannot be edited.

Dialog example of widget items in the status area¹ of a smartphone App:

Widget items type	Display	Description
-------------------	---------	-------------

(2, PushButtonDual) ¹ (4, List) ¹		Display for value symbols
--	---	---------------------------

¹ In the status area, widget items are read only and cannot be edited.

Relationship of widget items and data types for the referenced data points:

Widget item type	Data types
1, PushButton	RadioButton
2, PushButtonDual	RadioButton, Enumeration
3, Range	Numeric or TimeOfDay
4, List	Enumeration

2.9.5 read_datapoint - /api/menutree/read_datapoint

Request URI (HTTP GET):

http://mydevice/api/menutree/read_datapoint.format

Request example:

```
http://192.168.251.1/api/menutree/read_datapoint.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88&Id=878
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session
Id	878	(none)	Data point in the menu tree

Response body in JSON:

```
{
  "Data": {
    "Type": "Numeric"1,
    "Value": "28.0"2,
    "Unit": "°C",
    "EnumValue": "10"3
  }
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Data>
    <Type>Numeric1</Type>,
    <Value>28.0</Value>2
    <Unit>°C</Unit>
    <EnumValue>10</EnumValue>3
  </Data>
  <Result>...</Result>
</Service>
```

¹ All data types are supported

² The value is always returned as a string regardless of data type. The strings are UTF8 and JSON encoded.

³ In addition, the current enumeration is always returned during an enumeration as of version 1.1.0.

2.9.6 read_datapoint_direct - /api/menutree/read_datapoint_direct

Request URI (HTTP GET):

http://mydevice/api/menutree/read_datapoint_direct.format

Request example:

```
http://192.168.251.1/api/menutree/read_datapoint_direct.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88&SerialNumber=00FD00FF01F0&Address=0x102F1001&DpSubKey=0
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of a current session
SerialNumber	00FD00FF01F0	(none)	Unique device serial number
Address ¹	0x102F1001	(none)	Data point address
DpSubKey ¹	0	0	Supplement data point identification

¹ Inside a device can a data point be uniquely identified based on the parameters "Address" and "DpSubKey". The two parameters are included in the disclosure document for the device.

Response Body in JSON / XML:

The same as for service read_datapoint - /api/menutree/read_datapoint im Sec. 2.9.5.

2.9.7 datapoint_desc - /api/menutree/datapoint_desc

Request URI (HTTP GET):

http://mydevice/api/menutree/datapoint_desc.format

Request example:

```
http://192.168.251.1/api/menutree/datapoint_desc.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88&Id=878
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session
Id	878	(none)	Data point in the menu tree

Response body in JSON:

```
{
  "Description":
    {
      "Type": "..."1,
      ...
    }
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Description>
    <Type>...</Type>1
    ...
  </Description>
  <Result>...</Result>
</Service>
```

¹ Possible data types include String, Numeric, Enumeration, CheckBox, RadioButton, DateTime, TimeOfDay and Scheduler.

2.9.7.1 Data type String

Parameter in the data point description:

Parameter	Example	Description
Type	String	Data type
Value	MyPlant	Present value
Name	Plant name	Data point name
DialogType ¹	Normal, Password ¹	Sub-dialog type
MaxLength	21	Maximum string length (including end characters)

¹ Passwords are displayed using the placeholder “•” per character.


Response body in JSON for data type string:

```
{
  "Description": {
    "Type": "String",
    "Value": "MyPlant",
    "Name": "Plant name",
    "DialogType": "Normal",
    "MaxLength": "21",
  }
  "Result": ...
}
```

Response body in XML for data type string:

```
<Service>
  <Description>
    <Type>String</Type>
    <Value>MyPlant</Value>
    <Name>Plant name</Name>
    <DialogType>Normal</DialogType>
    <MaxLength>21</MaxLength>
  </Description>
  <Result>...</Result>
</Service>
```

Dialog example of web operation:



2.9.7.2 Data type: Numeric

Parameter in the data point description:

Parameter	Example	Description
Type	Numeric	Data point data type
Value	39.5	Present value
Unit	°C	Data point unit
Name	Comfort	Data point name
Min	24.0	Minimum value limitation
Max	67.4	Maximum value limitation
Resolution	0.5	Value resolution
FieldWidth	5	Maximum characters in the value (including prefixes or commas)
DecimalsDigits	1	Number of decimal points following the period
IsValid ¹	false	Data point has validity info
IsValid ¹	true	Data point validity info

¹ A data point can also be “invalid” in addition to the normal setting range. The actual data point is not longer relevant if “invalid”.


Response body in JSON for data type: Numeric:

```
{
  "Description": {
    "Type": "Numeric",
    "Value": "39.5",
    "Unit": "°C",
    "Name": "Cooling setpoint comfort",
    "Min": "24.0",
    "Max": "67.4",
    "Resolution": "0.5",
    "FieldWitdh": "5",
    "DecimalsDigits": "5",
    "IsValid": "false",
    "IsValid": "true",
  }
  "Result": ...
}
```

Response body in XML for data type: Numeric:

```
<Service>
  <Description>
    <Type>Numeric</Type>
    <Value>39.5</Value>
    <Unit>°C</Unit>
    <Name>Cooling setpoint comfort</Name>
    <Min>24.0</Min>
    <Max>67.4</Max>
    <Resolution>0.5</Resolution>
    <FieldWitdh>5</FieldWitdh>
    <DecimalsDigits>5</DecimalsDigits>
    <IsValid>>false</IsValid>
    <IsValid>>true</IsValid>
  </Description>
  <Result>...</Result>
</Service>
```

Dialog example of web operation



2.9.7.3 Data type: Enumeration

Parameter in the data point description:

Parameter	Example	Description
Type	Enumeration	Data point data type
Name	Weekday	Data point name
<i>Pro Enumeration value</i>		<i>Pro Enumeration value</i>
- Text	---, Monday, Wednesday, Sunday	- Enumeration text
- Value ¹	0, 1, 3, 7	- Enumeration value
- IsCurrentValue ²	true, false	- Labeling of present value

¹ Gaps in enumeration values permitted.

² Labeling whether this enumeration value corresponds to the currently set value.


Response body in JSON for data type: Enumeration:

```
{
  "Description": {
    "Type": "Enumeration",
    "Name": "Weekday",
    "Enums": [
      {
        "Text": "---",
        "Value": "0",
        "IsCurrentValue": "false"
      },
      {
        "Text": "Monday",
        "Value": "1",
        "IsCurrentValue": "true"
      },
      ...
    ]
  }
  "Result": ...
}
```

Response body in XML for data type: Enumeration:

```
<Service>
  <Description>
    <Type>Enumeration</Type>
    <Name>Weekday</Name>
    <Enums>
      <Enum>
        <Text>---</ValueText>
        <Value>0</Value>
        <IsCurrentValue>>false</IsCurrentValue>
      </Enum>
      <Enum>
        <Text>Monday</ValueText>
        <Value>1</Value>
        <IsCurrentValue>>true</IsCurrentValue>
      </Enum>
      ...
    </Enums>
  </Description>
  <Result>...</Result>
</Service>
```

Dialog example of web operation:



2.9.7.4 Data type: CheckBox

Parameter in the data point description:

Parameter	Example	Description
Type	CheckBox	Data point data type
Name	Active rooms	Data point name
<i>Per each visible checkbox</i> ¹ - Text - Significance - IsActive	Option1, Option2, Option3 2, 8, 32 true, false	<i>Per each visible checkbox</i> - Checkbox text - Checkbox valence - Checkbox state

¹ Gaps in valence of the boxes are permitted


Response body in JSON for data type: CheckBox:

```
{
  "Description": {
    "Type": "CheckBox",
    "Name": "Active rooms",
    "Boxes" : [
      {
        "Text": "Room 1",
        "Significance": "1",
        "IsActive": "true"
      },
      {
        "Text": "Room 2",
        "Significance": "2",
        "IsActive": "false"
      },
      ...
    ]
  }
  "Result": ...
}
```

Response body in XML for Data type CheckBox:

```
<Service>
  <Description>
    <Type>CheckBox</Type>
    <Name>Active rooms</Name>
    <Boxes>
      <Box>
        <Text>Room 1</Text>
        <Significance>1</Significance>
        <IsActive>true</IsActive>
      </Box>
      <Box>
        <Text>Room 2</Text>
        <Significance>2</Significance>
        <IsActive>>false</IsActive>
      </Box>
      ...
    </Boxes>
  </Description>
  <Result>...</Result>
</Service>
```

Dialog example of web operation:



2.9.7.5 Data type: RadioButton

Parameter in data point description:

Parameter	Example	Description
Type	RadioButton	Data point data type

Name	Active rooms	Data point name
<i>Per visible Radiobutton</i> ¹ - TextOpt0 - TextOpt1 - Significance - IsOpt1Active ²	OptionA, Off OptionB, On 2, 8, 32 true, false	<i>Per visible Radiobutton</i> - Button text for Option0 - Button text for Option1 - Valence of button Option1 - Current state on Option1

¹ Gaps in button valence is permitted.

Response body in JSON for data type: RadioButton:

```


{
  "Description": {
    "Type": "RadioButton",
    "Name": "Active rooms",
    "Buttons": [
      {
        "TextOpt0": "Room 1 inactive",
        "TextOpt1": "Room 1 active",
        "Significance": "1",
        "IsActive": "true"
      },
      {
        "TextOpt0": "Room 2 inactive",
        "TextOpt1": "Room 2 active",
        "Significance": "2",
        "IsActive": "false"
      }
    ],
    ...
  }
  "Result": ...
}
    
```

Response body in XML for Data type RadioButton:

```

<Service>
  <Description>
    <Type>RadioButton</Type>
    <Name>Active rooms</Name>
    <Buttons>
      <Button>
        <TextOpt0>Room 1 inactive</TextOpt0>
        <TextOpt1>Room 1 active</TextOpt1>
        <Significance>1</Significance>
        <IsActive>true</IsActive>
      </Button>
      <Button>
        <TextOpt0>Room 2 inactive</TextOpt0>
        <TextOpt1>Room 2 active</TextOpt1>
        <Significance>2</Significance>
        <IsActive>false</IsActive>
      </Button>
      ...
    </Buttons>
  </Description>
  <Result>...</Result>
</Service>
    
```

Dialog example of web operation:



2.9.7.6 Data type: DateTime

Parameter in the data point description:

Parameter	Example	Description
Type	DateTime	Data point data type
Name	Time & date	Data point name
Time ^{1,2} - Value_hh - Value_mm	22 15	Hours Minutes
Date ^{1,2} - Value_DD - Value_MM	30 04	Day of month Month
Year ^{1,2} - Value_YY	11	Year
IsValid ³	false	Data point has validity info
IsValid ³	true, false	Data point validity info

¹ All partial values are always two-digit and restricted by standard limits for time or date.

² The partial ranges “Time”, “Date” or “Year” may be invalid. Only valid partial values are mapped to the response.

³ A data point can also be “invalid” as an option in addition to the normal setting range. The actual data point value is no longer relevant if the data point is “invalid”.

Response body in JSON for data type: DateTime:


```
{
  "Description":
  {
    "Type": "DateTime",
    "Name": "Time & date",
    "Time":
    {
      "Value_hh": "22",
      "Value_mm": "15"
    },
    "Date":
    {
      "Value_DD": "30",
      "Value_MM": "04"
    },
    "Year":
    {
      "Value_YY": "11"
    },
    "IsValid": "false",
    "IsValid": "false",
  }
  "Result": ...
}
```

Response body in XML for data type: DateTime:

```

<Service>
  <Description>
    <Type>DateTime</Type>
    <Name>Time & date</Name>
    <Time>
      <Value_hh>22</Value_hh>
      <Value_mm>15</Value_mm>
    </Time>
    <Date>
      <Value_DD>30</Value_DD>
      <Value_MM>04</Value_MM>
    </Date>
    <Year>
      <Value_YY>11</Value_YY>
    </Year>
    <IsValid>false</IsValid>
  </Description>
  <Result>...</Result>
</Service>
    
```

Dialog example of web operation:



2.9.7.7 Data type: TimeOfDay

Parameter in the data point description:

Parameter	Example	Description
Type	TimeOfDay	Data point data type
Name	Overshoot time	Data point name
Unit	m:s	Unit
<i>Days</i> ^{1,2,4,5}		
- Value_DD	6	Partial value days
- Min	0	Minimum limitation
- Max	19	Maximum limitation
- Resolution	0	Value resolution
<i>Hour</i> ^{1,2,4,5}		
- Value_hh	22	Partial value Hours
- Min	0	Minimum limitation
- Max	23	Maximum limitation
- Resolution	0	Value resolution
<i>Minutes</i> ^{1,2,4,5}		
- Value_mm	33	Partial value minutes
- Min	0	Minimum limitation
- Max	59	Maximum limitation
- Resolution	0	Value resolution
<i>Seconds</i> ^{1,2,4,5}		
- Value_ss	55	Partial value Seconds
- Min	0	Minimum limitation
- Max	55	Maximum limitation

- Resolution	5	Value resolution
IsAbsolut	false	Time of day is absolute
IsValid ³	false	Data point has validity info
IsValid ³	true, false	Data point validity info

¹ A maximum of 2 partial values can be displayed.

² The individual partial values ““Days”, “Hour”, “Minutes” or “Seconds” may be invalid. Only valid partial values are mapped to the response.

³ A data point may also be “invalid” in addition to the optional, normal setting range. The actual data point value is no longer relevant is the data point is “invalid”.

⁴ The setting range of the data point is derived from the compiled partial value limitations. Using the example data above and assumed validity of “Minutes” and “Seconds”, results, for example, in a setting range of 00:00 to 59:55 (mm:ss).

⁵ The data point resolution is derived from the compiled partial value resolutions. Using the example data above that the assumed validity of “Minutes” and “Seconds”, results, for example, in a resolution of 00:05 (mm:ss).

Response body in JSON for data type TimeOfDay:


```
{
  "Description": {
    "Type": "TimeOfDay",
    "Name": "Overshoot time",
    "Unit": "m:s",
    "Minutes": {
      "Value_mm": "33",
      "Min": "0",
      "Max": "59",
      "Resolution": "0",
    },
    "Seconds": {
      "Value_ss": "55",
      "Min": "0",
      "Max": "55",
      "Resolution": "5",
    },
    "IsAbsolut": "false",
    "IsValid": "false",
    "IsValid": "false"
  }
  "Result": ...
}
```

Response body in XML for data type TimeOfDay:

```
<Service>
  <Description>
    <Type>TimeOfDay</Type>
    <Name>Overshoot time</Name>
    <Unit>m:s</Unit>
    <Minutes>
      <Value_mm>33</Value_mm>
      <Min>0</Min>
      <Max>59</Max>
      <Resolution>0</Resolution>
    </Minutes>
    <Seconds>
      <Value_ss>55</Value_ss>
      <Min>0</Min>
      <Max>55</Max>
      <Resolution>5</Resolution>
    </Seconds>
    <IsAbsolut>>false</IsAbsolut>
    <IsValid>>false</IsValid>
    <IsValid>>false</IsValid>
  </Description>
</Service>
```

```
</Description>
<Result>...</Result>
</Service>
```

Dialog example of web operation:



2.9.7.8 Data type: Scheduler

Parameter in the data point description:

Parameter	Example	Description
Type	Scheduler	Data point data type
Name	Scheduler program	Data point name
SchedulerType	5	Time switch type: 1: Domestic Hot Water (Field bus KNX) 2: On/Off (Field bus KNX) 3: HVAC (Field bus KNX) 4: Event (Field bus KNX) 5: Common (Field bus LPB)
EnumId	271	Time switch version
<i>Pro Enumeration value</i>		<i>Pro Enumeration value</i>
- Text	Comfort, PreComfort, Economy, Protection	- Enumeration text
- Value ¹	0, 1, 2, 3	- Enumeration value
<i>Switchpoint1</i> ^{1,3}		
- Sw1_IsValid ²	true	Switching point validity info
- Sw1_hh	06	(hours) Switching point time
- Sw1_mm	10	(minutes) Switching point time
- Sw1_Mode ⁴	1	Switching point operating mode
<i>Switchpoint2</i> ^{1,3}		
- Sw2_IsValid ²	true	Switching point validity info
- Sw2_hh	07	(hours) Switching point time
- Sw2_mm	10	(minutes) Switching point time
- Sw2_Mode ⁴	0	Switching point operating mode
<i>Switchpoint3</i> ^{1,3}		
- Sw3_IsValid ²	true	Switching point validity info
- Sw3_hh	08	(hours) Switching point time
- Sw3_mm	30	(minutes) Switching point time
- Sw3_Mode ⁴	1	Switching point operating mode
<i>Switchpoint4</i> ^{1,3}		
- Sw4_IsValid ²	true	Switching point validity info

- Sw4_hh	09	(hours) Switching point time
- Sw4_mm	30	(minutes) Switching point time
- Sw4_Mode ⁴	0	Switching point operating mode
<i>Switchpoint5</i> ^{1,3}		
- Sw5_IsValid ²	true	Switching point validity info
- Sw5_hh	15	(hours) Switching point time
- Sw5_mm	30	(minutes) Switching point time
- Sw5_Mode ⁴	1	Switching point operating mode
<i>Switchpoint6</i> ^{1,3}		
- Sw6_IsValid ²	true	Switching point validity info
- Sw6_hh	19	(hours) Switching point time
- Sw6_mm	30	(minutes) Switching point time
- Sw6_Mode ⁴	0	Switching point operating mode
<i>Switchpoint7</i> ^{1,3}		
- Sw7_IsValid ²	false	Switching point validity info
- Sw7_hh	00	(hours) Switching point time
- Sw7_mm	00	(minutes) Switching point time
- Sw7_Mode ⁴	0	Switching point operating mode
<i>Switchpoint8</i> ^{1,3}		
- Sw8_IsValid ²	false	Switching point validity info
- Sw8_hh	00	(hours) Switching point time
- Sw8_mm	00	(minutes) Switching point time
- Sw8_Mode ⁴	0	Switching point operating mode

¹ Partial values are always two digits and restricted by standard limits for time of day.

² A switching point can also be invalid. In this case, the associated attribute time and operating mode are irrelevant.

³ Only the number of switching points are mapped that the actual device is capable of supporting.

⁴ Operating mode encoding is based on EnumId and the actual device.

Response body in JSON for data type: Scheduler:

```
{
  "Description":
  {
    "Type": "Scheduler",
    "Name": " Monday",
    "SchedulerType": 3,
    "EnumId": "241",
    "Enums":
    [
      {
        "Text": "Comfort",
        "Value": "0"
      },
      {
        "Text": "Precomfort",
        "Value": "1"
      },
      {
        "Text": "Economy",
        "Value": "2"
      }
    ],
    "Switchpoint1":
    {
      "Sw1_IsValid": "true",
      "Sw1_hh": "06",
      "Sw1_mm": "10",
      "Sw1_Mode": "1"
    }
  }
}
```

```

    },
    "Switchpoint2":
    {
        "Sw2_IsValid": "true",
        "Sw2_hh": "07",
        "Sw2_mm": "10",
        "Sw2_Mode": "0"
    },
    "Switchpoint3":
    {
        "Sw3_IsValid": "true",
        "Sw3_hh": "08",
        "Sw3_mm": "30",
        "Sw3_Mode": "1"
    },
    "Switchpoint4":
    {
        "Sw4_IsValid": "true",
        "Sw4_hh": "09",
        "Sw4_mm": "30",
        "Sw4_Mode": "0"
    },
    "Switchpoint5":
    {
        "Sw5_IsValid": "true",
        "Sw5_hh": "15",
        "Sw5_mm": "30",
        "Sw5_Mode": "1"
    },
    "Switchpoint6":
    {
        "Sw6_IsValid": "true",
        "Sw6_hh": "19",
        "Sw6_mm": "30",
        "Sw6_Mode": "0"
    },
    "Switchpoint7":
    {
        "Sw7_IsValid": "false",
        "Sw7_hh": "00",
        "Sw7_mm": "00",
        "Sw7_Mode": "0"
    },
    "Switchpoint8":
    {
        "Sw8_IsValid": "false",
        "Sw8_hh": "00",
        "Sw8_mm": "00",
        "Sw8_Mode": "0"
    }
}
"Result": ...
}

```

Response body in XML for data type: Scheduler:

```

<Service>
  <Description>
    <Type>Scheduler</Type>
    <Name>Monday</Name>
    <SchedulerType>3</SchedulerType>
    <EnumId>241</EnumId>
    <Enums>
      <Enum>
        <Text>Comfort</Text>
        <Value>0</Value>
      </Enum>
      <Enum>
        <Text>Precomfort</Text>
        <Value>1</Value>
      </Enum>
      <Enum>
        <Text>Economy</Text>
        <Value>2</Value>
      </Enum>
    </Enums>
  </Description>
  <Switchpoint1>


```

```

        <Sw1_IsValid>true</Sw1_IsValid>
        <Sw1_hh>06</Sw1_hh>
        <Sw1_mm>10</Sw1_mm>
        <Sw1_Mode>1</Sw1_Mode>
    </Switchpoint1>
    <Switchpoint2>
        <Sw2_IsValid>true</Sw2_IsValid>
        <Sw2_hh>07</Sw2_hh>
        <Sw2_mm>10</Sw2_mm>
        <Sw2_Mode>0</Sw2_Mode>
    </Switchpoint2>
    <Switchpoint3>
        <Sw3_IsValid>true</Sw3_IsValid>
        <Sw3_hh>08</Sw3_hh>
        <Sw3_mm>30</Sw3_mm>
        <Sw3_Mode>1</Sw3_Mode>
    </Switchpoint3>
    <Switchpoint4>
        <Sw4_IsValid>true</Sw4_IsValid>
        <Sw4_hh>09</Sw4_hh>
        <Sw4_mm>30</Sw4_mm>
        <Sw4_Mode>0</Sw4_Mode>
    </Switchpoint4>
    <Switchpoint5>
        <Sw5_IsValid>true</Sw5_IsValid>
        <Sw5_hh>15</Sw5_hh>
        <Sw5_mm>30</Sw5_mm>
        <Sw5_Mode>1</Sw5_Mode>
    </Switchpoint5>
    <Switchpoint6>
        <Sw6_IsValid>true</Sw6_IsValid>
        <Sw6_hh>19</Sw6_hh>
        <Sw6_mm>30</Sw6_mm>
        <Sw6_Mode>0</Sw6_Mode>
    </Switchpoint6>
    <Switchpoint7>
        <Sw7_IsValid>false</Sw7_IsValid>
        <Sw7_hh>00</Sw7_hh>
        <Sw7_mm>00</Sw7_mm>
        <Sw7_Mode>0</Sw7_Mode>
    </Switchpoint7>
    <Switchpoint8>
        <Sw8_IsValid>false</Sw8_IsValid>
        <Sw8_hh>00</Sw8_hh>
        <Sw8_mm>00</Sw8_mm>
        <Sw8_Mode>0</Sw8_Mode>
    </Switchpoint8>
</Description>
<Result>...</Result>
</Service>

```

Dialog example of web operation:



Rules for type “5” time switch / Common (Field bus LPB):

- A time switch can have up to 8 switching points. The scheduler subtype is “0”.
- Switching points are always in pairs. The first switching point is always the switch-on and the second, the switch-off time.
- The time for the switching point must be within the range 00:00 – 24:00 and be within the typical resolution of 00:10. The operating device corrects times outside the resolution.

- The operating mode is not transferred among the daily time switches. Each daily time switch begins by default with operating mode “0”/Off.
- A switching point can be invalid. If all switching points on a time switch are invalid, the operating mode “0/Off” applies to the entire day.
- The switching points must be sorted chronologically in ascending order with invalid switching points at the end of the list. When writing via API, the sorting order is verified and corrected as needed.

Rules for type “1-4” time switch (Field bus KNX):

- A daily time switch can have 0 to 6 switching points.
- The switching points must be sorted chronologically in ascending order with invalid switching points at the very end.
- The time of the switching point must be within a range of 00:00 – 23:59.
- The operating mode is transferred between daily time switches.
- The operating mode of the last switching point from the previous day applies until the first switching point of the day (days 1-7, after day 7, returns to day 1). The special day program (8th day) is its own previous day.

Possible Enumerations Id:

- EnumId Default (0)
 - Off (0)
 - On (1)

- EnumId BW (215)
 - ~~Auto (0)~~ Auto (0)
 - Normal (1) Normal (1)
 - Reduziert (2) Reduced (2)
 - ~~Schutzbetrieb (3)~~ Protection (3)

- EnumId On/Off (235)
 - Off (0)
 - On (1)

- EnumId HVAC (241)
 - Komfort (0) Comfort (0)
 - Prekomfort (1) Precomfort (1)
 - Economy (2) Economy (2)
 - Schutzbetrieb (3) Protection (3)

- EnumId On/Off (273)
 - Aus (0) Off (0)
 - Ein (1) On (1)

- EnumId Jalousie (511)
 - Ab (0) Down (0)
 - Auf (1) Up (1)

- EnumId Szene (563)
 - Szene A (0) Scene A (0)

- Szene B (1) Scene B (1)

All enumeration texts are listed in the user language.

2.9.7.9 **Data type: Calendar**

Parameter in the data point description:

Parameter	Example	Description
Type	Calendar	Data point data type
Name	Calendar program	Data point name
Calendar01^{1,3} - Ca01_IsValid ² - Ca01_IsYearly ⁴ - Ca01_Mode - Ca01_1_DD - Ca01_1_MM - Ca01_1_YY - Ca01_1_hh - Ca01_1_mm - Ca01_2_DD - Ca01_2_MM - Ca01_2_YY - Ca01_2_hh - Ca01_2_mm	true true 1 01 02 13 00 00 01 03 13 23 59	Calendar entry validity info Annual, repeating Holiday (0) or special day (1) Period start: Day of month Period start: Month Period start: Year Period start: Hours Period start: Minutes Period end: Day of month Period end: Month Period end: Year Period end: Hours Period end: Minutes
Calendar02^{1,3} - Ca02_IsValid ² - Ca02_IsYearly ⁴ - Ca02_Mode - Ca02_1_DD - Ca02_1_MM - Ca02_1_YY - Ca02_1_hh - Ca02_1_mm - Ca02_2_DD - Ca02_2_MM - Ca02_2_YY - Ca02_2_hh - Ca02_2_mm	true true 0 01 02 13 00 00 01 03 13 23 59	Calendar entry validity info Annual, repeating Holiday (0) or special day (1) Period start: Day of month Period start: Month Period start: Year Period start: Hours Period start: Minutes Period end: Day of month Period end: Month Period end: Year Period end: Hours Period end: Minutes
Calendar03^{1,3} - Ca03_IsValid ² - Ca03_IsYearly ⁴ - Ca03_Mode - Ca03_1_DD - Ca03_1_MM - Ca03_1_YY - Ca03_1_hh - Ca03_1_mm - Ca03_2_DD - Ca03_2_MM - Ca03_2_YY - Ca03_2_hh - Ca03_2_mm	true false 1 01 02 13 00 00 01 03 13 23 59	Calendar entry validity info Annual, repeating Holiday (0) or special day (1) Period start: Day of month Period start: Month Period start: Year Period start: Hours Period start: Minutes Period end: Day of month Period end: Month Period end: Year Period end: Hours Period end: Minutes
Calendar04^{1,3} - Ca04_IsValid ²	true	Calendar entry validity info

- Ca04_IsYearly ⁴	false	Annual, repeating
- Ca04_Mode	1	Holiday (0) or special day (1)
- Ca04_1_DD	01	Period start: Day of month
- Ca04_1_MM	02	Period start: Month
- Ca04_1_YY	13	Period start: Year
- Ca04_1_hh	00	Period start: Hours
- Ca04_1_mm	00	Period start: Minutes
- Ca04_2_DD	01	Period end: Day of month
- Ca04_2_MM	03	Period end: Month
- Ca04_2_YY	13	Period end: Year
- Ca04_2_hh	23	Period end: Hours
- Ca04_2_mm	59	Period end: Minutes
<i>Calendar05^{1,3}</i>		
- Ca05_IsValid ²	true	Calendar entry validity info
- Ca05_IsYearly ⁴	false	Annual, repeating
- Ca05_Mode	1	Holiday (0) or special day (1)
- Ca05_1_DD	01	Period start: Day of month
- Ca05_1_MM	02	Period start: Month
- Ca05_1_YY	13	Period start: Year
- Ca05_1_hh	00	Period start: Hours
- Ca05_1_mm	00	Period start: Minutes
- Ca05_2_DD	01	Period end: Day of month
- Ca05_2_MM	03	Period end: Month
- Ca05_2_YY	13	Period end: Year
- Ca05_2_hh	23	Period end: Hours
- Ca05_2_mm	59	Period end: Minutes
<i>Calendar06^{1,3}</i>		
- Ca06_IsValid ²	true	Calendar entry validity info
- Ca06_IsYearly ⁴	true	Annual, repeating
- Ca06_Mode	1	Holiday (0) or special day (1)
- Ca06_1_DD	01	Period start: Day of month
- Ca06_1_MM	02	Period start: Month
- Ca06_1_YY	13	Period start: Year
- Ca06_1_hh	00	Period start: Hours
- Ca06_1_mm	00	Period start: Minutes
- Ca06_2_DD	01	Period end: Day of month
- Ca06_2_MM	03	Period end: Month
- Ca06_2_YY	13	Period end: Year
- Ca06_2_hh	23	Period end: Hours
- Ca06_2_mm	59	Period end: Minutes
<i>Calendar07^{1,3}</i>		
- Ca07_IsValid ²	true	Calendar entry validity info
- Ca07_IsYearly ⁴	false	Annual, repeating
- Ca07_Mode	1	Holiday (0) or special day (1)
- Ca07_1_DD	01	Period start: Day of month
- Ca07_1_MM	02	Period start: Month
- Ca07_1_YY	13	Period start: Year
- Ca07_1_hh	00	Period start: Hours
- Ca07_1_mm	00	Period start: Minutes
- Ca07_2_DD	01	Period end: Day of month
- Ca07_2_MM	03	Period end: Month
- Ca07_2_YY	13	Period end: Year
- Ca07_2_hh	23	Period end: Hours
- Ca07_2_mm	59	Period end: Minutes
<i>Calendar08^{1,3}</i>		
- Ca08_IsValid ²	true	Calendar entry validity info

- Ca08_IsYearly ⁴	false	Annual, repeating
- Ca08_Mode	1	Holiday (0) or special day (1)
- Ca08_1_DD	01	Period start: Day of month
- Ca08_1_MM	02	Period start: Month
- Ca08_1_YY	13	Period start: Year
- Ca08_1_hh	00	Period start: Hours
- Ca08_1_mm	00	Period start: Minutes
- Ca08_2_DD	01	Period end: Day of month
- Ca08_2_MM	03	Period end: Month
- Ca08_2_YY	13	Period end: Year
- Ca08_2_hh	23	Period end: Hours
- Ca08_2_mm	59	Period end: Minutes
<i>Calendar09^{1,3}</i>		
- Ca09_IsValid ²	true	Calendar entry validity info
- Ca09_IsYearly ⁴	false	Annual, repeating
- Ca09_Mode	1	Holiday (0) or special day (1)
- Ca09_1_DD	01	Period start: Day of month
- Ca09_1_MM	02	Period start: Month
- Ca09_1_YY	13	Period start: Year
- Ca09_1_hh	00	Period start: Hours
- Ca09_1_mm	00	Period start: Minutes
- Ca09_2_DD	01	Period end: Day of month
- Ca09_2_MM	03	Period end: Month
- Ca09_2_YY	13	Period end: Year
- Ca09_2_hh	23	Period end: Hours
- Ca09_2_mm	59	Period end: Minutes
<i>Calendar10^{1,3}</i>		
- Ca10_IsValid ²	true	Calendar entry validity info
- Ca10_IsYearly ⁴	false	Annual, repeating
- Ca10_Mode	0	Holiday (0) or special day (1)
- Ca10_1_DD	01	Period start: Day of month
- Ca10_1_MM	02	Period start: Month
- Ca10_1_YY	13	Period start: Year
- Ca10_1_hh	00	Period start: Hours
- Ca10_1_mm	00	Period start: Minutes
- Ca10_2_DD	01	Period end: Day of month
- Ca10_2_MM	03	Period end: Month
- Ca10_2_YY	13	Period end: Year
- Ca10_2_hh	23	Period end: Hours
- Ca10_2_mm	59	Period end: Minutes
<i>Calendar11^{1,3}</i>		
- Ca11_IsValid ²	true	Calendar entry validity info
- Ca11_IsYearly ⁴	false	Annual, repeating
- Ca11_Mode	1	Holiday (0) or special day (1)
- Ca11_1_DD	01	Period start: Day of month
- Ca11_1_MM	02	Period start: Month
- Ca11_1_YY	13	Period start: Year
- Ca11_1_hh	00	Period start: Hours
- Ca11_1_mm	00	Period start: Minutes
- Ca11_2_DD	01	Period end: Day of month
- Ca11_2_MM	03	Period end: Month
- Ca11_2_YY	13	Period end: Year
- Ca11_2_hh	23	Period end: Hours
- Ca11_2_mm	59	Period end: Minutes
<i>Calendar12^{1,3}</i>		
- Ca12_IsValid ²	true	Calendar entry validity info

- Ca12_IsYearly ⁴	false	Annual, repeating
- Ca12_Mode	1	Holiday (0) or special day (1)
- Ca12_1_DD	01	Period start: Day of month
- Ca12_1_MM	02	Period start: Month
- Ca12_1_YY	13	Period start: Year
- Ca12_1_hh	00	Period start: Hours
- Ca12_1_mm	00	Period start: Minutes
- Ca12_2_DD	01	Period end: Day of month
- Ca12_2_MM	03	Period end: Month
- Ca12_2_YY	13	Period end: Year
- Ca12_2_hh	23	Period end: Hours
- Ca12_2_mm	59	Period end: Minutes
<i>Calendar13</i> ^{1,3}		
- Ca13_IsValid ²	true	Calendar entry validity info
- Ca13_IsYearly ⁴	false	Annual, repeating
- Ca13_Mode	1	Holiday (0) or special day (1)
- Ca13_1_DD	01	Period start: Day of month
- Ca13_1_MM	02	Period start: Month
- Ca13_1_YY	13	Period start: Year
- Ca13_1_hh	00	Period start: Hours
- Ca13_1_mm	00	Period start: Minutes
- Ca13_2_DD	01	Period end: Day of month
- Ca13_2_MM	03	Period end: Month
- Ca13_2_YY	13	Period end: Year
- Ca13_2_hh	23	Period end: Hours
- Ca13_2_mm	59	Period end: Minutes
<i>Calendar14</i> ^{1,3}		
- Ca14_IsValid ²	true	Calendar entry validity info
- Ca14_IsYearly ⁴	false	Annual, repeating
- Ca14_Mode	1	Holiday (0) or special day (1)
- Ca14_1_DD	01	Period start: Day of month
- Ca14_1_MM	02	Period start: Month
- Ca14_1_YY	13	Period start: Year
- Ca14_1_hh	00	Period start: Hours
- Ca14_1_mm	00	Period start: Minutes
- Ca14_2_DD	01	Period end: Day of month
- Ca14_2_MM	03	Period end: Month
- Ca14_2_YY	13	Period end: Year
- Ca14_2_hh	23	Period end: Hours
- Ca14_2_mm	59	Period end: Minutes
<i>Calendar15</i> ^{1,3}		
- Ca15_IsValid ²	true	Calendar entry validity info
- Ca15_IsYearly ⁴	false	Annual, repeating
- Ca15_Mode	1	Holiday (0) or special day (1)
- Ca15_1_DD	01	Period start: Day of month
- Ca15_1_MM	02	Period start: Month
- Ca15_1_YY	13	Period start: Year
- Ca15_1_hh	00	Period start: Hours
- Ca15_1_mm	00	Period start: Minutes
- Ca15_2_DD	01	Period end: Day of month
- Ca15_2_MM	03	Period end: Month
- Ca15_2_YY	13	Period end: Year
- Ca15_2_hh	23	Period end: Hours
- Ca15_2_mm	59	Period end: Minutes
<i>Calendar16</i> ^{1,3}		
- Ca16_IsValid ²	true	Calendar entry validity info

- Ca16_IsYearly ⁴	true	Annual, repeating
- Ca16_Mode	1	Holiday (0) or special day (1)
- Ca16_1_DD	01	Period start: Day of month
- Ca16_1_MM	02	Period start: Month
- Ca16_1_YY	13	Period start: Year
- Ca16_1_hh	00	Period start: Hours
- Ca16_1_mm	00	Period start: Minutes
- Ca16_2_DD	01	Period end: Day of month
- Ca16_2_MM	03	Period end: Month
- Ca16_2_YY	13	Period end: Year
- Ca16_2_hh	23	Period end: Hours
- Ca16_2_mm	59	Period end: Minutes

- ¹ Partial values are always two digit and restricted by standard limits for time-of-day.
- ² A calendar entry can also be invalid. The associated attributes are irrelevant in this case.
- ³ Only as many calendar entries are mapped as the actual device supports.
- ⁴ If a calendar entry is repeated annual, the entries with years are not valid.

Response body in JSON for data type Calendar:

```
{
  "Description":
  {
    "Type": "Calendar",
    "Name": "Holiday/special day",

    "Calendar01":
    {
      "Ca01_IsValid": "true",
      "Ca01_IsYearly": "true",
      "Ca01_Mode": "0",
      "Ca01_1_DD": "21",
      "Ca01_1_MM": "01",
      "Ca01_1_YY": "55",
      "Ca01_1_hh": "00",
      "Ca01_1_mm": "00",
      "Ca01_2_DD": "23",
      "Ca01_2_MM": "01",
      "Ca01_2_YY": "55",
      "Ca01_2_hh": "23",
      "Ca01_2_mm": "59"
    },
    "Calendar02":
    {
      "Ca02_IsValid": "true",
      "Ca02_IsYearly": "false",
      "Ca02_Mode": "1",
      "Ca02_1_DD": "15",
      "Ca02_1_MM": "02",
      "Ca02_1_YY": "15",
      "Ca02_1_hh": "20",
      "Ca02_1_mm": "30",
      "Ca02_2_DD": "23",
      "Ca02_2_MM": "03",
      "Ca02_2_YY": "15",
      "Ca02_2_hh": "22",
      "Ca02_2_mm": "59"
    },
    "Calendar03":
    {
      "Ca03_IsValid": "false",
      "Ca03_IsYearly": "false",
      "Ca03_Mode": "0",
      "Ca03_1_DD": "01",
      "Ca03_1_MM": "01",
      "Ca03_1_YY": "00",
      "Ca03_1_hh": "00",
      "Ca03_1_mm": "00",
      "Ca03_2_DD": "01",

```

```
        "Ca03_2_MM": "01",
        "Ca03_2_YY": "00",
        "Ca03_2_hh": "23",
        "Ca03_2_mm": "59"
    },
    "Calendar04":
    {
        "Ca04_IsValid": "false",
        "Ca04_IsYearly": "false",
        "Ca04_Mode": "0",
        "Ca04_1_DD": "01",
        "Ca04_1_MM": "01",
        "Ca04_1_YY": "00",
        "Ca04_1_hh": "00",
        "Ca04_1_mm": "00",
        "Ca04_2_DD": "01",
        "Ca04_2_MM": "01",
        "Ca04_2_YY": "00",
        "Ca04_2_hh": "23",
        "Ca04_2_mm": "59"
    },
    "Calendar05":
    {
        "Ca05_IsValid": "false",
        "Ca05_IsYearly": "false",
        "Ca05_Mode": "0",
        "Ca05_1_DD": "01",
        "Ca05_1_MM": "01",
        "Ca05_1_YY": "00",
        "Ca05_1_hh": "00",
        "Ca05_1_mm": "00",
        "Ca05_2_DD": "01",
        "Ca05_2_MM": "01",
        "Ca05_2_YY": "00",
        "Ca05_2_hh": "23",
        "Ca05_2_mm": "59"
    },
    "Calendar06":
    {
        "Ca06_IsValid": "false",
        "Ca06_IsYearly": "false",
        "Ca06_Mode": "0",
        "Ca06_1_DD": "01",
        "Ca06_1_MM": "01",
        "Ca06_1_YY": "00",
        "Ca06_1_hh": "00",
        "Ca06_1_mm": "00",
        "Ca06_2_DD": "01",
        "Ca06_2_MM": "01",
        "Ca06_2_YY": "00",
        "Ca06_2_hh": "23",
        "Ca06_2_mm": "59"
    },
    "Calendar07":
    {
        "Ca07_IsValid": "false",
        "Ca07_IsYearly": "false",
        "Ca07_Mode": "0",
        "Ca07_1_DD": "01",
        "Ca07_1_MM": "01",
        "Ca07_1_YY": "00",
        "Ca07_1_hh": "00",
        "Ca07_1_mm": "00",
        "Ca07_2_DD": "01",
        "Ca07_2_MM": "01",
        "Ca07_2_YY": "00",
        "Ca07_2_hh": "23",
        "Ca07_2_mm": "59"
    },
    "Calendar08":
    {
        "Ca08_IsValid": "false",
        "Ca08_IsYearly": "false",
        "Ca08_Mode": "0",
        "Ca08_1_DD": "01",
        "Ca08_1_MM": "01",
```

```
"Ca08_1_YY": "00",
"Ca08_1_hh": "00",
"Ca08_1_mm": "00",
"Ca08_2_DD": "01",
"Ca08_2_MM": "01",
"Ca08_2_YY": "00",
"Ca08_2_hh": "23",
"Ca08_2_mm": "59"
},
"Calendar09":
{
    "Ca09_IsValid": "false",
    "Ca09_IsYearly": "false",
    "Ca09_Mode": "0",
    "Ca09_1_DD": "01",
    "Ca09_1_MM": "01",
    "Ca09_1_YY": "00",
    "Ca09_1_hh": "00",
    "Ca09_1_mm": "00",
    "Ca09_2_DD": "01",
    "Ca09_2_MM": "01",
    "Ca09_2_YY": "00",
    "Ca09_2_hh": "23",
    "Ca09_2_mm": "59"
},
"Calendar10":
{
    "Ca10_IsValid": "false",
    "Ca10_IsYearly": "false",
    "Ca10_Mode": "0",
    "Ca10_1_DD": "01",
    "Ca10_1_MM": "01",
    "Ca10_1_YY": "00",
    "Ca10_1_hh": "00",
    "Ca10_1_mm": "00",
    "Ca10_2_DD": "01",
    "Ca10_2_MM": "01",
    "Ca10_2_YY": "00",
    "Ca10_2_hh": "23",
    "Ca10_2_mm": "59"
},
"Calendar11":
{
    "Ca11_IsValid": "false",
    "Ca11_IsYearly": "false",
    "Ca11_Mode": "0",
    "Ca11_1_DD": "01",
    "Ca11_1_MM": "01",
    "Ca11_1_YY": "00",
    "Ca11_1_hh": "00",
    "Ca11_1_mm": "00",
    "Ca11_2_DD": "01",
    "Ca11_2_MM": "01",
    "Ca11_2_YY": "00",
    "Ca11_2_hh": "23",
    "Ca11_2_mm": "59"
},
"Calendar12":
{
    "Ca12_IsValid": "false",
    "Ca12_IsYearly": "false",
    "Ca12_Mode": "0",
    "Ca12_1_DD": "01",
    "Ca12_1_MM": "01",
    "Ca12_1_YY": "00",
    "Ca12_1_hh": "00",
    "Ca12_1_mm": "00",
    "Ca12_2_DD": "01",
    "Ca12_2_MM": "01",
    "Ca12_2_YY": "00",
    "Ca12_2_hh": "23",
    "Ca12_2_mm": "59"
},
"Calendar13":
{
    "Ca13_IsValid": "false",
```

```

        "Ca13_IsYearly": "false",
        "Ca13_Mode": "0",
        "Ca13_1_DD": "01",
        "Ca13_1_MM": "01",
        "Ca13_1_YY": "00",
        "Ca13_1_hh": "00",
        "Ca13_1_mm": "00",
        "Ca13_2_DD": "01",
        "Ca13_2_MM": "01",
        "Ca13_2_YY": "00",
        "Ca13_2_hh": "23",
        "Ca13_2_mm": "59"
    },
    "Calendar14":
    {
        "Ca14_IsValid": "false",
        "Ca14_IsYearly": "false",
        "Ca14_Mode": "0",
        "Ca14_1_DD": "01",
        "Ca14_1_MM": "01",
        "Ca14_1_YY": "00",
        "Ca14_1_hh": "00",
        "Ca14_1_mm": "00",
        "Ca14_2_DD": "01",
        "Ca14_2_MM": "01",
        "Ca14_2_YY": "00",
        "Ca14_2_hh": "23",
        "Ca14_2_mm": "59"
    },
    "Calendar15":
    {
        "Ca15_IsValid": "false",
        "Ca15_IsYearly": "false",
        "Ca15_Mode": "0",
        "Ca15_1_DD": "01",
        "Ca15_1_MM": "01",
        "Ca15_1_YY": "00",
        "Ca15_1_hh": "00",
        "Ca15_1_mm": "00",
        "Ca15_2_DD": "01",
        "Ca15_2_MM": "01",
        "Ca15_2_YY": "00",
        "Ca15_2_hh": "23",
        "Ca15_2_mm": "59"
    },
    "Calendar16":
    {
        "Ca16_IsValid": "false",
        "Ca16_IsYearly": "false",
        "Ca16_Mode": "0",
        "Ca16_1_DD": "01",
        "Ca16_1_MM": "01",
        "Ca16_1_YY": "00",
        "Ca16_1_hh": "00",
        "Ca16_1_mm": "00",
        "Ca16_2_DD": "01",
        "Ca16_2_MM": "01",
        "Ca16_2_YY": "00",
        "Ca16_2_hh": "23",
        "Ca16_2_mm": "59"
    }
}

    "Result": ...
}

```

Response body in XML for data type Calendar:

```

<Service>
  <Description>
    <Type>Calendar</Type>
    <Name>Holidays/special days</Name>
    <Calendar01>
      <Ca01_IsValid>true</Ca01_IsValid>
      <Ca01_IsYearly>true</Ca01_IsYearly>
      <Ca01_Mode>0</Ca01_Mode>
    </Calendar01>
  </Description>
</Service>

```

```

<Ca01_1_DD>21</Ca01_1_DD>
<Ca01_1_MM>01</Ca01_1_MM>
<Ca01_1_YY>55</Ca01_1_YY>
<Ca01_1_hh>00</Ca01_1_hh>
<Ca01_1_mm>00</Ca01_1_mm>
<Ca01_2_DD>23</Ca01_2_DD>
<Ca01_2_MM>01</Ca01_2_MM>
<Ca01_2_YY>55</Ca01_2_YY>
<Ca01_2_hh>23</Ca01_2_hh>
<Ca01_2_mm>59</Ca01_2_mm>
</Calendar01>
<Calendar02>
  <Ca02_IsValid>true</Ca02_IsValid>
  <Ca02_IsYearly>false</Ca02_IsYearly>
  <Ca02_Mode>1</Ca02_Mode>
  <Ca02_1_DD>15</Ca02_1_DD>
  <Ca02_1_MM>02</Ca02_1_MM>
  <Ca02_1_YY>15</Ca02_1_YY>
  <Ca02_1_hh>20</Ca02_1_hh>
  <Ca02_1_mm>30</Ca02_1_mm>
  <Ca02_2_DD>23</Ca02_2_DD>
  <Ca02_2_MM>03</Ca02_2_MM>
  <Ca02_2_YY>15</Ca02_2_YY>
  <Ca02_2_hh>22</Ca02_2_hh>
  <Ca02_2_mm>59</Ca02_2_mm>
</Calendar02>
<Calendar03>
  <Ca03_IsValid>false</Ca03_IsValid>
  <Ca03_IsYearly>false</Ca03_IsYearly>
  <Ca03_Mode>0</Ca03_Mode>
  <Ca03_1_DD>01</Ca03_1_DD>
  <Ca03_1_MM>01</Ca03_1_MM>
  <Ca03_1_YY>00</Ca03_1_YY>
  <Ca03_1_hh>00</Ca03_1_hh>
  <Ca03_1_mm>00</Ca03_1_mm>
  <Ca03_2_DD>01</Ca03_2_DD>
  <Ca03_2_MM>01</Ca03_2_MM>
  <Ca03_2_YY>00</Ca03_2_YY>
  <Ca03_2_hh>23</Ca03_2_hh>
  <Ca03_2_mm>59</Ca03_2_mm>
</Calendar03>
<Calendar04>
  <Ca04_IsValid>false</Ca04_IsValid>
  <Ca04_IsYearly>false</Ca04_IsYearly>
  <Ca04_Mode>0</Ca04_Mode>
  <Ca04_1_DD>01</Ca04_1_DD>
  <Ca04_1_MM>01</Ca04_1_MM>
  <Ca04_1_YY>00</Ca04_1_YY>
  <Ca04_1_hh>00</Ca04_1_hh>
  <Ca04_1_mm>00</Ca04_1_mm>
  <Ca04_2_DD>01</Ca04_2_DD>
  <Ca04_2_MM>01</Ca04_2_MM>
  <Ca04_2_YY>00</Ca04_2_YY>
  <Ca04_2_hh>23</Ca04_2_hh>
  <Ca04_2_mm>59</Ca04_2_mm>
</Calendar04>
<Calendar05>
  <Ca05_IsValid>false</Ca05_IsValid>
  <Ca05_IsYearly>false</Ca05_IsYearly>
  <Ca05_Mode>0</Ca05_Mode>
  <Ca05_1_DD>01</Ca05_1_DD>
  <Ca05_1_MM>01</Ca05_1_MM>
  <Ca05_1_YY>00</Ca05_1_YY>
  <Ca05_1_hh>00</Ca05_1_hh>
  <Ca05_1_mm>00</Ca05_1_mm>
  <Ca05_2_DD>01</Ca05_2_DD>
  <Ca05_2_MM>01</Ca05_2_MM>
  <Ca05_2_YY>00</Ca05_2_YY>
  <Ca05_2_hh>23</Ca05_2_hh>
  <Ca05_2_mm>59</Ca05_2_mm>
</Calendar05>
<Calendar06>
  <Ca06_IsValid>false</Ca06_IsValid>
  <Ca06_IsYearly>false</Ca06_IsYearly>
  <Ca06_Mode>0</Ca06_Mode>
  <Ca06_1_DD>01</Ca06_1_DD>

```

```

<Ca06_1_MM>01</Ca06_1_MM>
<Ca06_1_YY>00</Ca06_1_YY>
<Ca06_1_hh>00</Ca06_1_hh>
<Ca06_1_mm>00</Ca06_1_mm>
<Ca06_2_DD>01</Ca06_2_DD>
<Ca06_2_MM>01</Ca06_2_MM>
<Ca06_2_YY>00</Ca06_2_YY>
<Ca06_2_hh>23</Ca06_2_hh>
<Ca06_2_mm>59</Ca06_2_mm>
</Calendar06>
<Calendar07>
  <Ca07_IsValid>>false</Ca07_IsValid>
  <Ca07_IsYearly>>false</Ca07_IsYearly>
  <Ca07_Mode>0</Ca07_Mode>
  <Ca07_1_DD>01</Ca07_1_DD>
  <Ca07_1_MM>01</Ca07_1_MM>
  <Ca07_1_YY>00</Ca07_1_YY>
  <Ca07_1_hh>00</Ca07_1_hh>
  <Ca07_1_mm>00</Ca07_1_mm>
  <Ca07_2_DD>01</Ca07_2_DD>
  <Ca07_2_MM>01</Ca07_2_MM>
  <Ca07_2_YY>00</Ca07_2_YY>
  <Ca07_2_hh>23</Ca07_2_hh>
  <Ca07_2_mm>59</Ca07_2_mm>
</Calendar07>
<Calendar08>
  <Ca08_IsValid>>false</Ca08_IsValid>
  <Ca08_IsYearly>>false</Ca08_IsYearly>
  <Ca08_Mode>0</Ca08_Mode>
  <Ca08_1_DD>01</Ca08_1_DD>
  <Ca08_1_MM>01</Ca08_1_MM>
  <Ca08_1_YY>00</Ca08_1_YY>
  <Ca08_1_hh>00</Ca08_1_hh>
  <Ca08_1_mm>00</Ca08_1_mm>
  <Ca08_2_DD>01</Ca08_2_DD>
  <Ca08_2_MM>01</Ca08_2_MM>
  <Ca08_2_YY>00</Ca08_2_YY>
  <Ca08_2_hh>23</Ca08_2_hh>
  <Ca08_2_mm>59</Ca08_2_mm>
</Calendar08>
<Calendar09>
  <Ca09_IsValid>>false</Ca09_IsValid>
  <Ca09_IsYearly>>false</Ca09_IsYearly>
  <Ca09_Mode>0</Ca09_Mode>
  <Ca09_1_DD>01</Ca09_1_DD>
  <Ca09_1_MM>01</Ca09_1_MM>
  <Ca09_1_YY>00</Ca09_1_YY>
  <Ca09_1_hh>00</Ca09_1_hh>
  <Ca09_1_mm>00</Ca09_1_mm>
  <Ca09_2_DD>01</Ca09_2_DD>
  <Ca09_2_MM>01</Ca09_2_MM>
  <Ca09_2_YY>00</Ca09_2_YY>
  <Ca09_2_hh>23</Ca09_2_hh>
  <Ca09_2_mm>59</Ca09_2_mm>
</Calendar09>
<Calendar10>
  <Ca10_IsValid>>false</Ca10_IsValid>
  <Ca10_IsYearly>>false</Ca10_IsYearly>
  <Ca10_Mode>0</Ca10_Mode>
  <Ca10_1_DD>01</Ca10_1_DD>
  <Ca10_1_MM>01</Ca10_1_MM>
  <Ca10_1_YY>00</Ca10_1_YY>
  <Ca10_1_hh>00</Ca10_1_hh>
  <Ca10_1_mm>00</Ca10_1_mm>
  <Ca10_2_DD>01</Ca10_2_DD>
  <Ca10_2_MM>01</Ca10_2_MM>
  <Ca10_2_YY>00</Ca10_2_YY>
  <Ca10_2_hh>23</Ca10_2_hh>
  <Ca10_2_mm>59</Ca10_2_mm>
</Calendar10>
<Calendar11>
  <Ca11_IsValid>>false</Ca11_IsValid>
  <Ca11_IsYearly>>false</Ca11_IsYearly>
  <Ca11_Mode>0</Ca11_Mode>
  <Ca11_1_DD>01</Ca11_1_DD>
  <Ca11_1_MM>01</Ca11_1_MM>

```

```


<Ca11_1_YY>00</Ca11_1_YY>
<Ca11_1_hh>00</Ca11_1_hh>
<Ca11_1_mm>00</Ca11_1_mm>
<Ca11_2_DD>01</Ca11_2_DD>
<Ca11_2_MM>01</Ca11_2_MM>
<Ca11_2_YY>00</Ca11_2_YY>
<Ca11_2_hh>23</Ca11_2_hh>
<Ca11_2_mm>59</Ca11_2_mm>
</Calendar11>
<Calendar12>
  <Ca12_IsValid>>false</Ca12_IsValid>
  <Ca12_IsYearly>>false</Ca12_IsYearly>
  <Ca12_Mode>0</Ca12_Mode>
  <Ca12_1_DD>01</Ca12_1_DD>
  <Ca12_1_MM>01</Ca12_1_MM>
  <Ca12_1_YY>00</Ca12_1_YY>
  <Ca12_1_hh>00</Ca12_1_hh>
  <Ca12_1_mm>00</Ca12_1_mm>
  <Ca12_2_DD>01</Ca12_2_DD>
  <Ca12_2_MM>01</Ca12_2_MM>
  <Ca12_2_YY>00</Ca12_2_YY>
  <Ca12_2_hh>23</Ca12_2_hh>
  <Ca12_2_mm>59</Ca12_2_mm>
</Calendar12>
<Calendar13>
  <Ca13_IsValid>>false</Ca13_IsValid>
  <Ca13_IsYearly>>false</Ca13_IsYearly>
  <Ca13_Mode>0</Ca13_Mode>
  <Ca13_1_DD>01</Ca13_1_DD>
  <Ca13_1_MM>01</Ca13_1_MM>
  <Ca13_1_YY>00</Ca13_1_YY>
  <Ca13_1_hh>00</Ca13_1_hh>
  <Ca13_1_mm>00</Ca13_1_mm>
  <Ca13_2_DD>01</Ca13_2_DD>
  <Ca13_2_MM>01</Ca13_2_MM>
  <Ca13_2_YY>00</Ca13_2_YY>
  <Ca13_2_hh>23</Ca13_2_hh>
  <Ca13_2_mm>59</Ca13_2_mm>
</Calendar13>
<Calendar14>
  <Ca14_IsValid>>false</Ca14_IsValid>
  <Ca14_IsYearly>>false</Ca14_IsYearly>
  <Ca14_Mode>0</Ca14_Mode>
  <Ca14_1_DD>01</Ca14_1_DD>
  <Ca14_1_MM>01</Ca14_1_MM>
  <Ca14_1_YY>00</Ca14_1_YY>
  <Ca14_1_hh>00</Ca14_1_hh>
  <Ca14_1_mm>00</Ca14_1_mm>
  <Ca14_2_DD>01</Ca14_2_DD>
  <Ca14_2_MM>01</Ca14_2_MM>
  <Ca14_2_YY>00</Ca14_2_YY>
  <Ca14_2_hh>23</Ca14_2_hh>
  <Ca14_2_mm>59</Ca14_2_mm>
</Calendar14>
<Calendar15>
  <Ca15_IsValid>>false</Ca15_IsValid>
  <Ca15_IsYearly>>false</Ca15_IsYearly>
  <Ca15_Mode>0</Ca15_Mode>
  <Ca15_1_DD>01</Ca15_1_DD>
  <Ca15_1_MM>01</Ca15_1_MM>
  <Ca15_1_YY>00</Ca15_1_YY>
  <Ca15_1_hh>00</Ca15_1_hh>
  <Ca15_1_mm>00</Ca15_1_mm>
  <Ca15_2_DD>01</Ca15_2_DD>
  <Ca15_2_MM>01</Ca15_2_MM>
  <Ca15_2_YY>00</Ca15_2_YY>
  <Ca15_2_hh>23</Ca15_2_hh>
  <Ca15_2_mm>59</Ca15_2_mm>
</Calendar15>
<Calendar16>
  <Ca16_IsValid>>false</Ca16_IsValid>
  <Ca16_IsYearly>>false</Ca16_IsYearly>
  <Ca16_Mode>0</Ca16_Mode>
  <Ca16_1_DD>01</Ca16_1_DD>
  <Ca16_1_MM>01</Ca16_1_MM>
  <Ca16_1_YY>00</Ca16_1_YY>

```

```

        <Ca16_1_hh>00</Ca16_1_hh>
        <Ca16_1_mm>00</Ca16_1_mm>
        <Ca16_2_DD>01</Ca16_2_DD>
        <Ca16_2_MM>01</Ca16_2_MM>
        <Ca16_2_YY>00</Ca16_2_YY>
        <Ca16_2_hh>23</Ca16_2_hh>
        <Ca16_2_mm>59</Ca16_2_mm>
    </Calendar16>
</Description>
<Result>
    <Success>true</Success>
</Result>
</Service>
    
```

Dialog example of web operation:



Calendar rules

- A calendar can have 0 to 16 entries.
- Overlapping entries in the calendar is not actively prevented.
- The complete calendar must be written at one time so that a sort on the device does not restart each time there is a change. Otherwise, possible entries are not overwritten.

2.9.8 datapoint_desc_direct - /api/menutree/datapoint_desc_direct

Request URI (HTTP GET):

http://mydevice/api/menutree/datapoint_desc_direct.format

Request example:

```
http://192.168.251.1/api/menutree/datapoint_desc_direct.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88&SerialNumber=00FD00FF01F0&Address=0x102F1001&DpSubKey=0
```

Request Parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session
SerialNumber	00FD00FF01F0	(none)	Unique device serial number

Address ¹	0x102F1001	(none)	Data point address
DpSubKey ¹	0	0	Supplemental data point identification

¹ Within a device can a data point e uniquely identified on a device based on parameter "Address" and "DpSubKey". These two parameters are included in the disclosure document for the device.

Response Body in JSON / XML:

The same as for service datapoint_desc - /api/menutree/datapoint_desc in Sec. 2.9.7.

2.9.9 write_datapoint - /api/menutree/write_datapoint

Request URI (HTTP GET):

http://mydevice/api/menutree/write_datapoint.format

Request example:

```
http://192.168.251.1/api/menutree/write_datapoint.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88&Id=878&Type=Numeric&Value=49.0
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session
Id	878	(none)	Data point in the menu tree
Type ¹	Numeric	(none)	The data point type for write
Value ¹	49.0, ...	(none)	The data point value for write

¹ The parameter value or its coding is based on the applicable data type. Possible data types include String, Numeric, Enum, CheckBox, RadioButton, DateTime, TimeOfDay and Scheduler.

Data points may only be written as needed and never periodically, since the number of write cycles to the memory blocks is limited on the operated devices.

Value encoding based on data type

Data type	Value fields	Example Value	Example query
String	Value	MyText ¹	Value=MeinText ¹
Numeric	Value, IsValid ²	49.0 ⁵ , true	Value=49.0 ⁵ &IsValid=true ²
Enumeration	Value	7	Value=7
CheckBox	Value	535 ³	Value=535 ³
RadioButton	Value	3534 ³	Value=3534 ³
DateTime	Value_hh ⁴ , Value_mm ⁴ , Value_DD ⁴ , Value_MM ⁴ , Value_YY ⁴ , IsValid ²	22, 15, 30, 12, 12, true (22:15 ⁵ , 30.12.12 ⁵ , true)	Value_hh=22&Value_mm=15&Value_DD=30&Value_MM=04&Value_YY=12&IsValid=true ^{2,5}
TimeOfDay	Day ⁴ , Hour ⁴ , Minutes ⁴ , Seconds ⁴ , IsValid ²	28, 13, 45, 58, true (28 ⁵ , 13:45:58 ⁵)	Value_DD=28&Value_hh=13&Value_mm=45&Value_ss=58&IsValid=true ^{2,5}
Scheduler ⁶	Sw1_IsValid Sw1_hh, Sw1_mm Sw1_Mode Sw2_IsValid Sw2_hh, Sw2_mm Sw2_Mode Sw3_IsValid Sw3_hh, Sw3_mm	true 06, 00 1 true 07, 00 0 true 08, 30	Sw1_IsValid=true& Sw1_hh=06&Sw1_mm=00&Sw1_Mode=1& Sw2_IsValid=true& Sw2_hh=07&Sw2_mm=00&Sw2_Mode=0& Sw3_IsValid=true& Sw3_hh=08&Sw3_mm=30&Sw3_Mode=1& Sw4_IsValid=true& Sw4_hh=09&Sw4_mm=30&Sw4_Mode=0& Sw5_IsValid=false&

Ca04_1_DD	00	Ca05_2_mm=00&
Ca04_1_MM	00	
Ca04_1_YY	00	Ca06_IsValid=false&Ca06_IsYearly=false&
Ca04_1_hh	00	Ca06_Mode=0&Ca06_1_DD=00&
Ca04_1_mm	00	Ca06_1_MM=02&Ca06_1_YY=00&
Ca04_2_DD	00	Ca06_1_hh=00&Ca06_1_mm=00&
Ca04_2_MM	00	Ca06_2_DD=00&Ca06_2_MM=00&
Ca04_2_YY	00	Ca06_2_YY=00&Ca06_2_hh=00&
Ca04_2_hh	00	Ca06_2_mm=00&
Ca04_2_mm	00	
Ca05_IsValid	False	Ca07_IsValid=false&Ca07_IsYearly=false&
Ca05_IsYearly	False	Ca07_Mode=0&Ca07_1_DD=00&
Ca05_Mode	0	Ca07_1_MM=02&Ca07_1_YY=00&
Ca05_1_DD	00	Ca07_1_hh=00&Ca07_1_mm=00&
Ca05_1_MM	00	Ca07_2_DD=00&Ca07_2_MM=00&
Ca05_1_YY	00	Ca07_2_YY=00&Ca07_2_hh=00&
Ca05_1_hh	00	Ca07_2_mm=00&
Ca05_1_mm	00	
Ca05_2_DD	00	Ca08_IsValid=false&Ca08_IsYearly=false&
Ca05_2_MM	00	Ca08_Mode=0&Ca08_1_DD=00&
Ca05_2_YY	00	Ca08_1_MM=02&Ca08_1_YY=00&
Ca05_2_hh	00	Ca08_1_hh=00&Ca08_1_mm=00&
Ca05_2_mm	00	Ca08_2_DD=00&Ca08_2_MM=00&
Ca06_IsValid	False	Ca08_2_YY=00&Ca08_2_hh=00&
Ca06_IsYearly	False	Ca08_2_mm=00&
Ca06_Mode	0	
Ca06_1_DD	00	Ca09_IsValid=false&Ca09_IsYearly=false&
Ca06_1_MM	00	Ca09_Mode=0&Ca09_1_DD=00&
Ca06_1_YY	00	Ca09_1_MM=02&Ca09_1_YY=00&
Ca06_1_hh	00	Ca09_1_hh=00&Ca09_1_mm=00&
Ca06_1_mm	00	Ca09_2_DD=00&Ca09_2_MM=00&
Ca06_2_DD	00	Ca09_2_YY=00&Ca09_2_hh=00&
Ca06_2_MM	00	Ca09_2_mm=00&
Ca06_2_YY	00	
Ca06_2_hh	00	Ca10_IsValid=false&Ca10_IsYearly=false&
Ca06_2_mm	00	Ca10_Mode=0&Ca10_1_DD=00&
Ca07_IsValid	False	Ca10_1_MM=02&Ca10_1_YY=00&
Ca07_IsYearly	False	Ca10_1_hh=00&Ca10_1_mm=00&
Ca07_Mode	0	Ca10_2_DD=00&Ca10_2_MM=00&
Ca07_1_DD	00	Ca10_2_YY=00&Ca10_2_hh=00&
Ca07_1_MM	00	Ca10_2_mm=00&
Ca07_1_YY	00	
Ca07_1_hh	00	Ca11_IsValid=false&Ca11_IsYearly=false&
Ca07_1_mm	00	Ca11_Mode=0&Ca11_1_DD=00&
Ca07_2_DD	00	Ca11_1_MM=02&Ca11_1_YY=00&
Ca07_2_MM	00	Ca11_1_hh=00&Ca11_1_mm=00&
Ca07_2_YY	00	Ca11_2_DD=00&Ca11_2_MM=00&
Ca07_2_hh	00	Ca11_2_YY=00&Ca11_2_hh=00&
Ca07_2_mm	00	
Ca08_IsValid	False	
Ca08_IsYearly	False	
Ca08_Mode	0	

Ca08_1_DD	00	Ca11_2_mm=00&
Ca08_1_MM	00	
Ca08_1_YY	00	Ca12_IsValid=false&Ca12_IsYearly=false&
Ca08_1_hh	00	Ca12_Mode=0&Ca12_1_DD=00&
Ca08_1_mm	00	Ca12_1_MM=02&Ca12_1_YY=00&
Ca08_2_DD	00	Ca12_1_hh=00&Ca12_1_mm=00&
Ca08_2_MM	00	Ca12_2_DD=00&Ca12_2_MM=00&
Ca08_2_YY	00	Ca12_2_YY=00&Ca12_2_hh=00&
Ca08_2_hh	00	Ca12_2_mm=00&
Ca08_2_mm	00	
Ca09_IsValid	False	Ca13_IsValid=false&Ca13_IsYearly=false&
Ca09_IsYearly	False	Ca13_Mode=0&Ca13_1_DD=00&
Ca09_Mode	0	Ca13_1_MM=02&Ca13_1_YY=00&
Ca09_1_DD	00	Ca13_1_hh=00&Ca13_1_mm=00&
Ca09_1_MM	00	Ca13_2_DD=00&Ca13_2_MM=00&
Ca09_1_YY	00	Ca13_2_YY=00&Ca13_2_hh=00&
Ca09_1_hh	00	Ca13_2_mm=00&
Ca09_1_mm	00	
Ca09_2_DD	00	Ca14_IsValid=false&Ca14_IsYearly=false&
Ca09_2_MM	00	Ca14_Mode=0&Ca14_1_DD=00&
Ca09_2_YY	00	Ca14_1_MM=02&Ca14_1_YY=00&
Ca09_2_hh	00	Ca14_1_hh=00&Ca14_1_mm=00&
Ca09_2_mm	00	Ca14_2_DD=00&Ca14_2_MM=00&
Ca10_IsValid	False	Ca14_2_YY=00&Ca14_2_hh=00&
Ca10_IsYearly	False	Ca14_2_mm=00&
Ca10_Mode	0	
Ca10_1_DD	00	Ca15_IsValid=false&Ca15_IsYearly=false&
Ca10_1_MM	00	Ca15_Mode=0&Ca15_1_DD=00&
Ca10_1_YY	00	Ca15_1_MM=02&Ca15_1_YY=00&
Ca10_1_hh	00	Ca15_1_hh=00&Ca15_1_mm=00&
Ca10_1_mm	00	Ca15_2_DD=00&Ca15_2_MM=00&
Ca10_2_DD	00	Ca15_2_YY=00&Ca15_2_hh=00&
Ca10_2_MM	00	Ca15_2_mm=00&
Ca10_2_YY	00	
Ca10_2_hh	00	Ca16_IsValid=false&Ca16_IsYearly=false&
Ca10_2_mm	00	Ca16_Mode=0&Ca16_1_DD=00&
Ca11_IsValid	False	Ca16_1_MM=02&Ca16_1_YY=00&
Ca11_IsYearly	False	Ca16_1_hh=00&Ca16_1_mm=00&
Ca11_Mode	0	Ca16_2_DD=00&Ca16_2_MM=00&
Ca11_1_DD	00	Ca16_2_YY=00&Ca16_2_hh=00&
Ca11_1_MM	00	Ca16_2_mm=00
Ca11_1_YY	00	
Ca11_1_hh	00	
Ca11_1_mm	00	
Ca11_2_DD	00	
Ca11_2_MM	00	
Ca11_2_YY	00	
Ca11_2_hh	00	
Ca11_2_mm	00	
Ca12_IsValid	False	
Ca12_IsYearly	False	
Ca12_Mode	0	

Ca12_1_DD	00	
Ca12_1_MM	00	
Ca12_1_YY	00	
Ca12_1_hh	00	
Ca12_1_mm	00	
Ca12_2_DD	00	
Ca12_2_MM	00	
Ca12_2_YY	00	
Ca12_2_hh	00	
Ca12_2_mm	00	
Ca13_IsValid	False	
Ca13_IsYearly	False	
Ca13_Mode	0	
Ca13_1_DD	00	
Ca13_1_MM	00	
Ca13_1_YY	00	
Ca13_1_hh	00	
Ca13_1_mm	00	
Ca13_2_DD	00	
Ca13_2_MM	00	
Ca13_2_YY	00	
Ca13_2_hh	00	
Ca13_2_mm	00	
Ca14_IsValid	False	
Ca14_IsYearly	False	
Ca14_Mode	0	
Ca14_1_DD	00	
Ca14_1_MM	00	
Ca14_1_YY	00	
Ca14_1_hh	00	
Ca14_1_mm	00	
Ca14_2_DD	00	
Ca14_2_MM	00	
Ca14_2_YY	00	
Ca14_2_hh	00	
Ca14_2_mm	00	
Ca15_IsValid	False	
Ca15_IsYearly	False	
Ca15_Mode	0	
Ca15_1_DD	00	
Ca15_1_MM	00	
Ca15_1_YY	00	
Ca15_1_hh	00	
Ca15_1_mm	00	
Ca15_2_DD	00	
Ca15_2_MM	00	
Ca15_2_YY	00	
Ca15_2_hh	00	
Ca15_2_mm	00	
Ca16_IsValid	False	
Ca16_IsYearly	False	
Ca16_Mode	0	

Ca16_1_DD	00	
Ca16_1_MM	00	
Ca16_1_YY	00	
Ca16_1_hh	00	
Ca16_1_mm	00	
Ca16_2_DD	00	
Ca16_2_MM	00	
Ca16_2_YY	00	
Ca16_2_hh	00	
Ca16_2_mm	00	

¹ Strings must be URL encoded at handover.

² The value "IsValid" need only be set if the data point description sets the field to "IsValid".

³ The value corresponds to the sum of valence of all active checkboxes or radio buttons.

⁴ All visible partial fields of the data point must be set.

⁵ The values must be on the grid of the resolution. This is once again in API verified and the values for write are corrected as needed.

⁶ All attributes of existing switching points must be set. As an exception, undefined switching points are considered "invalid" and the associated attributes are set to value "0".

⁷ The entire calendar must be once again written to prevent restarting sort on the devices for each change. Otherwise, possible entries may be overwritten. As an exception, undefined switching points are considered "invalid" and the associated attributes are set to value "0".

Prior to writing a data point, the following checks are conducted. The data point is not described if a minimum of one check is unsuccessful, and a corresponding exception is returned.

Overview of checks

Data type	Checks
All data types	- Correct data type
String	- String is URL encoded
Numeric	- Value is within the (dynamic and status) limits - Value is numeric - "IsValid" value exists, if needed
Enumeration	- Value is within static limits - Value is numeric
CheckBox	- Value is numeric - All visible boxes are set
RadioButton	- Value is numeric - All visible boxes are set
DateTime	- Partial values are numeric - Partial values are within the static limits - "IsValid" value exists, if needed
TimeOfDay	- Partial values are numeric - Partial values are within static limits - "IsValid" value exists, if needed
Scheduler	- Partial values are numeric - Time of partial values are within the day limits 00:00 – 24:00
Calendar	- Partial values are numeric - Time of partial values are within the day limits 00:00 – 23:59

Response body in JSON, if the value could be written:

```
{
  "Result":
```

```

    {
        "Success": "true"
    }

```

Response body in XML, if the value could be written:

```

<Service>
  <Result>
    <Success>true</Success>
  </Result>
</Service>

```

Response body in JSON, if the value could not be written:

```

{
  "Result": {
    "Success": "false",
    "Error": {
      "Txt": "Write failed",
      "Nr": "3"
    }
  }
}

```

Response body in XML, if the value could not be written:

```

<Service>
  <Result>
    <Success>>false</Success>
    <Error>
      <Txt>Write failed</Txt>
      <Nr>3</Nr>
    </Error>
  </Result>
</Service>

```

2.9.10 write_datapoint_direct - /api/menutree/write_datapoint_direct

Request URI (HTTP GET):

http://mydevice/api/menutree/write_datapoint_direct.format

Request Example:

```

http://192.168.251.1/api/menutree/write_datapoint_direct.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88&SerialNumber=00FD00FF01F0&Address=0x102F1001&DpSubKey=0&Type=Numeric&Value=49.0

```

Request Parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session
SerialNumber	00FD00FF01F0	(none)	Unique device serial number
Address ¹	0x102F1001	(none)	Data point address
DpSubKey ¹	0	0	Supplemental data point identification
Type ²	Numeric	(none)	Data point type for write
Value ²	49.0, ...	(none)	Data point value for write

¹ Within a device can a data point be uniquely identified on a device based on parameter "Address" and "DpSubKey". These two parameters are included in the disclosure document for the device.

² The parameter value or its coding depends on the applicable data type. Possible data types include String, Numeric, Enumeration, CheckBox, RadioButton, DateTime, TimeOfDay and Scheduler.

Data points may only be described as needed and never periodically, since the number of write cycles is limited on the storage blocks of the operated devices.

Response Body in JSON / XML:

The same as for service write_datapoint - /api/menutree/write_datapoint in Sec. 2.9.9.

2.10 Energy cost allocator services

Function name	Application
version	Eca services version information
download	File download energy cost report

2.10.1 version - /api/eca/version

Request URI (HTTP GET):

<http://mydevice/api/eca/version.format>

Request example:

`http://192.168.251.1/api/eca/version.json`

The response content is the same as for service version - /api/version (Sec. 2.3.1).

2.10.2 download - /api/eca/download

Request URI (HTTP GET):

<http://mydevice/api/eca/download.format>

Request Example:

`http://192.168.251.1/api/eca/download.json?SessionId=0bc991a1-04eb-4a7c-8371-4ab648ec8a88&Type=CSV`

Request parameter:

Parameter	Example	Default value	Description
SessionId	0bc991a1-04eb-4a7c-...	(none)	SessionId of the current session of user group service or administrator
Type	xml, csv	xml	File type for download

Response body in JSON:

```
{
  "Download": {
    "Content-Type": "application/vnd.ms-excel",
    "Content-Disposition": "attachment",
    "filename": "consumption_data_20130305.csv",
    "Data":
    ";;;;;;;;;;;;;
    Plant information;;;;;;;;;;;;;
    ;;;;;;;;;;;;;;
    Plant name;Device address;Device type;Serial number;IP address;File created on;;File
    version;;;;;;;;;;;;;
    OZW772.250;0.2.150;OZW772.250;00FD00FEFF00;192.168.251.1;12:27:05.03.2013;1.00;;;;;;;;;;;;;
    ;;;;;;;;;;;;;;
    ;;;;;;;;;;;;;;
    Meter data;;;;;;;;;;;;;
    ;;;;;;;;;;;;;;
    Device information;;;Meter information;;;Current values;;;Meter state;;;Last due day;;Last but
    one due day;;Calendar monthly values;;;;;;;;;;;;;Start value Web server;;
    Device name;Device address;Device type;Serial number;Meter name;Medium;Production
    number;Identification number;Unit;Current value;Time of day;Date;Operating hours;Meter state;Time
    of
    day;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Va
    lue;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Current value;Time of day;Date
    ;;;;;;;;;;;;;;
    ;;;;;;;;;;;;;;
    ;;;;;;;;;;;;;;
    Device information;;;Meter information;;;Last values;;;Meter state;;;Last due day;;Last but one
    due day;;Calendar monthly values;;;;;;;;;;;;;Start value Web server;;
    Device name;Device address;Device type;Serial number;Meter name;Medium;Production
    number;Identification number;Unit;Current value;Time of day;Date;Operating hours;Meter state;Time
    of
    day;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Value;Date;Va
```



```
03.2013;16:38:51;On;\r\n06.03.2013;16:53:51;On;\r\n06.03.2013;17:08:51;On;\r\n06.03.2013;17:23:51;O
n;\r\n06.03.2013;17:24:43;On;\r\n06.03.2013;17:27:37;On;\r\n06.03.2013;17:29:28;On;\r\n06.03.2013;1
7:32:25;On;\r\n06.03.2013;17:38:52;On;\r\n06.03.2013;17:53:51;On;\r\n06.03.2013;18:08:51;On;\r\n06.
03.2013;18:23:51;On;\r\n06.03.2013;18:38:51;On;\r\n06.03.2013;18:53:51;On;\r\n06.03.2013;19:08:51;O
n;\r\n06.03.2013;19:23:51;On;\r\n06.03.2013;19:38:51;On;\r\n06.03.2013;19:53:51;On;\r\n06.03.2013;2
0:08:51;On;\r\n06.03.2013;20:23:51;On;\r\n06.03.2013;20:38:51;On;\r\n06.03.2013;20:53:52;On;\r\n06.
03.2013;21:08:51;On;\r\n06.03.2013;21:23:51;On;\r\n06.03.2013;21:38:51;On;\r\n06.03.2013;21:53:51;O
n;\r\n06.03.2013;22:08:51;On;\r\n06.03.2013;22:23:51;On;\r\n06.03.2013;22:38:51;On;\r\n06.03.2013;2
2:53:51;On;\r\n06.03.2013;23:08:51;On;\r\n06.03.2013;23:23:51;On;\r\n06.03.2013;23:38:51;On;\r\n06.
03.2013;23:53:51;On;\r\n07.03.2013;00:08:52;On;\r\n07.03.2013;00:23:51;On;\r\n07.03.2013;00:38:51;O
n;\r\n07.03.2013;00:53:51;On;\r\n07.03.2013;01:08:51;On;\r\n07.03.2013;01:23:51;On;\r\n07.03.2013;0
1:38:51;On;\r\n07.03.2013;01:53:51;On;\r\n07.03.2013;02:08:51;On;\r\n07.03.2013;02:23:51;On;\r\n07.
03.2013;02:38:51;On;\r\n07.03.2013;02:53:51;On;\r\n07.03.2013;03:08:51;On;\r\n07.03.2013;03:23:51;O
n;\r\n07.03.2013;03:38:51;On;\r\n07.03.2013;03:53:51;On;\r\n07.03.2013;04:08:51;On;\r\n07.03.2013;0
4:23:51;On;\r\n07.03.2013;04:38:51;On;\r\n07.03.2013;04:53:52;On;\r\n07.03.2013;05:08:51;On;\r\n07.
03.2013;05:23:51;On;\r\n07.03.2013;05:38:51;On;\r\n07.03.2013;05:53:51;On;\r\n07.03.2013;06:08:51;O
n;\r\n07.03.2013;06:23:51;On;\r\n07.03.2013;06:38:51;On;\r\n07.03.2013;06:53:51;On;\r\n07.03.2013;0
6:57:20;On;\r\n07.03.2013;07:25:40;On;\r\n07.03.2013;07:40:39;On;\r\n07.03.2013;07:43:28;On;\r\n07.
03.2013;07:58:27;On;\r\n07.03.2013;08:13:27;On;\r\n07.03.2013;08:28:27;On;\r\n07.03.2013;08:43:27;O
n;\r\n07.03.2013;08:58:27;On;\r\n07.03.2013;09:13:27;On;\r\n07.03.2013;09:28:27;On;\r\n07.03.2013;0
9:43:27;On;\r\n07.03.2013;09:58:27;On;\r\n07.03.2013;10:13:27;On;\r\n07.03.2013;10:28:27;On;\r\n07.
03.2013;10:43:27;On;\r\n07.03.2013;10:58:27;On;\r\n07.03.2013;11:13:27;On;\r\n07.03.2013;11:28:27;O
n;\r\n07.03.2013;11:43:27;On;\r\n07.03.2013;11:58:27;On;\r\n07.03.2013;12:12:25;On;\r\n07.03.2013;1
2:16:47;On;\r\n07.03.2013;12:31:46;On;\r\n07.03.2013;12:46:46;On;\r\n07.03.2013;13:01:46;On;\r\n07.
03.2013;13:16:46;On;\r\n07.03.2013;13:31:46;On;\r\n07.03.2013;13:46:46;On;\r\n07.03.2013;14:01:46;O
n;\r\n07.03.2013;14:16:46;On;\r\n07.03.2013;14:31:46;On;\r\n07.03.2013;14:32:48;On;\r\n07.03.2013;1
4:51:45;On;\r\n07.03.2013;15:01:18;On;\r\n07.03.2013;15:16:17;On;\r\n07.03.2013;15:19:20;On;\r\n07.
03.2013;15:28:15;On;\r\n07.03.2013;15:41:50;On;\r\n07.03.2013;15:45:34;On;\r\n07.03.2013;15:52:15;O
n;\r\n07.03.2013;15:58:18;On;\r\n07.03.2013;16:02:39;On;\r\n07.03.2013;16:02:51;On;\r\n07.03.2013;1
6:06:56;On;\r\n07.03.2013;16:14:10;On;\r\n07.03.2013;16:21:53;On;\r\n07.03.2013;16:23:19;On;\r\n07.
03.2013;16:25:37;On;\r\n11.03.2013;14:15:14;On;\r\n11.03.2013;14:30:13;On;\r\n11.03.2013;14:45:13;O
n;\r\n11.03.2013;15:00:13;On;\r\n11.03.2013;15:15:13;On;\r\n11.03.2013;15:30:13;On;\r\n11.03.2013;1
5:45:13;On;\r\n11.03.2013;16:00:13;On;\r\n11.03.2013;16:15:13;On;\r\n11.03.2013;16:30:13;On;\r\n11.
03.2013;16:45:13;On;\r\n11.03.2013;17:00:13;On;\r\n11.03.2013;17:15:13;On;\r\n11.03.2013;17:30:13;O
n;\r\n11.03.2013;17:45:13;On;\r\n11.03.2013;18:00:13;On;\r\n11.03.2013;18:15:13;On;\r\n11.03.2013;1
8:30:13;On;\r\n11.03.2013;18:45:13;On;\r\n11.03.2013;19:00:13;On;\r\n11.03.2013;19:15:13;On;\r\n11.
03.2013;19:30:13;On;\r\n11.03.2013;19:45:13;On;\r\n11.03.2013;20:00:13;On;\r\n11.03.2013;20:15:13;O
n;\r\n11.03.2013;20:30:13;On;\r\n11.03.2013;20:45:13;On;\r\n11.03.2013;21:00:13;On;\r\n11.03.2013;2
1:15:13;On;\r\n11.03.2013;21:30:14;On;\r\n11.03.2013;21:45:13;On;\r\n11.03.2013;22:00:13;On;\r\n11.
03.2013;22:15:13;On;\r\n11.03.2013;22:30:13;On;\r\n11.03.2013;22:45:13;On;\r\n11.03.2013;23:00:13;O
n;\r\n11.03.2013;23:15:13;On;\r\n11.03.2013;23:30:13;On;\r\n11.03.2013;23:45:13;On;\r\n12.03.2013;0
0:00:13;On;\r\n12.03.2013;00:15:13;On;\r\n12.03.2013;00:30:13;On;\r\n12.03.2013;00:45:13;On;\r\n12.
03.2013;01:00:13;On;\r\n12.03.2013;01:15:13;On;\r\n12.03.2013;01:30:13;On;\r\n12.03.2013;01:45:13;O
n;\r\n12.03.2013;02:00:13;On;\r\n12.03.2013;02:15:13;On;\r\n12.03.2013;02:30:13;On;\r\n12.03.2013;0
2:45:13;On;\r\n12.03.2013;03:00:13;On;\r\n12.03.2013;03:15:13;On;\r\n12.03.2013;03:30:13;On;\r\n12.
03.2013;03:45:13;On;\r\n12.03.2013;04:00:13;On;\r\n12.03.2013;04:15:14;On;\r\n12.03.2013;04:30:13;O
n;\r\n12.03.2013;04:45:13;On;\r\n12.03.2013;05:00:13;On;\r\n12.03.2013;05:15:13;On;\r\n12.03.2013;0
5:30:13;On;\r\n12.03.2013;05:45:13;On;\r\n12.03.2013;06:00:13;On;\r\n12.03.2013;06:15:13;On;\r\n12.
03.2013;06:30:13;On;\r\n12.03.2013;06:45:13;On;\r\n12.03.2013;13:15:55;On;\r\n12.03.2013;13:30:54;O
n;\r\n"
},
  "Result": {
    "Success": "true"
  }
}
```

Response body in XML:

```
<Service>
  <Download>
    <Content-Type>application/vnd.ms-excel</Content-Type>
    <Content-Disposition>attachment</Content-Disposition>
    <Content-Encoding/>
    <Filename>trend_data_1_20130312.csv</Filename>
    <Data>
Plant name:OZW772.250; Trend channel 1:test; Query interval:30s; Date;Time of day;Home > 0.2.150
OZW772.250 > Message receiver: Message inhibition; 06.03.2013;07:10:10;On; 06.03.2013;07:11:31;On;
06.03.2013;07:13:19;On; 06.03.2013;07:28:18;On; 06.03.2013;07:28:44;On; 06.03.2013;07:44:30;On;
06.03.2013;07:58:43;On; 06.03.2013;09:52:44;On; 06.03.2013;10:07:43;On; 06.03.2013;11:19:02;On;
06.03.2013;11:22:38;On; 06.03.2013;11:26:29;On; 06.03.2013;11:29:21;On; 06.03.2013;11:35:39;On;
06.03.2013;11:45:37;On; 06.03.2013;12:00:36;On; 06.03.2013;12:07:14;On; 06.03.2013;12:09:03;On;
06.03.2013;12:12:26;On; 06.03.2013;12:16:24;On; 06.03.2013;12:31:23;On; 06.03.2013;12:45:47;On;
06.03.2013;13:00:46;On; 06.03.2013;13:09:46;On; 06.03.2013;13:16:41;On; 06.03.2013;13:31:40;On;
06.03.2013;13:32:09;On; 06.03.2013;13:40:38;On; 06.03.2013;13:55:37;On; 06.03.2013;14:14:10;On;
06.03.2013;15:18:59;On; 06.03.2013;15:29:09;On; 06.03.2013;15:38:52;On; 06.03.2013;15:53:52;On;
06.03.2013;16:08:51;On; 06.03.2013;16:23:51;On; 06.03.2013;16:38:51;On; 06.03.2013;16:53:51;On;
```

```

06.03.2013;17:08:51;On; 06.03.2013;17:23:51;On; 06.03.2013;17:24:43;On; 06.03.2013;17:27:37;On;
06.03.2013;17:29:28;On; 06.03.2013;17:32:25;On; 06.03.2013;17:38:52;On; 06.03.2013;17:53:51;On;
06.03.2013;18:08:51;On; 06.03.2013;18:23:51;On; 06.03.2013;18:38:51;On; 06.03.2013;18:53:51;On;
06.03.2013;19:08:51;On; 06.03.2013;19:23:51;On; 06.03.2013;19:38:51;On; 06.03.2013;19:53:51;On;
06.03.2013;20:08:51;On; 06.03.2013;20:23:51;On; 06.03.2013;20:38:51;On; 06.03.2013;20:53:52;On;
06.03.2013;21:08:51;On; 06.03.2013;21:23:51;On; 06.03.2013;21:38:51;On; 06.03.2013;21:53:51;On;
06.03.2013;22:08:51;On; 06.03.2013;22:23:51;On; 06.03.2013;22:38:51;On; 06.03.2013;22:53:51;On;
06.03.2013;23:08:51;On; 06.03.2013;23:23:51;On; 06.03.2013;23:38:51;On; 06.03.2013;23:53:51;On;
07.03.2013;00:08:52;On; 07.03.2013;00:23:51;On; 07.03.2013;00:38:51;On; 07.03.2013;00:53:51;On;
07.03.2013;01:08:51;On; 07.03.2013;01:23:51;On; 07.03.2013;01:38:51;On; 07.03.2013;01:53:51;On;
07.03.2013;02:08:51;On; 07.03.2013;02:23:51;On; 07.03.2013;02:38:51;On; 07.03.2013;02:53:51;On;
07.03.2013;03:08:51;On; 07.03.2013;03:23:51;On; 07.03.2013;03:38:51;On; 07.03.2013;03:53:51;On;
07.03.2013;04:08:51;On; 07.03.2013;04:23:51;On; 07.03.2013;04:38:51;On; 07.03.2013;04:53:52;On;
07.03.2013;05:08:51;On; 07.03.2013;05:23:51;On; 07.03.2013;05:38:51;On; 07.03.2013;05:53:51;On;
07.03.2013;06:08:51;On; 07.03.2013;06:23:51;On; 07.03.2013;06:38:51;On; 07.03.2013;06:53:51;On;
07.03.2013;06:57:20;On; 07.03.2013;07:25:40;On; 07.03.2013;07:40:39;On; 07.03.2013;07:43:28;On;
07.03.2013;07:58:27;On; 07.03.2013;08:13:27;On; 07.03.2013;08:28:27;On; 07.03.2013;08:43:27;On;
07.03.2013;08:58:27;On; 07.03.2013;09:13:27;On; 07.03.2013;09:28:27;On; 07.03.2013;09:43:27;On;
07.03.2013;09:58:27;On; 07.03.2013;10:13:27;On; 07.03.2013;10:28:27;On; 07.03.2013;10:43:27;On;
07.03.2013;10:58:27;On; 07.03.2013;11:13:27;On; 07.03.2013;11:28:27;On; 07.03.2013;11:43:27;On;
07.03.2013;11:58:27;On; 07.03.2013;12:12:25;On; 07.03.2013;12:16:47;On; 07.03.2013;12:31:46;On;
07.03.2013;12:46:46;On; 07.03.2013;13:01:46;On; 07.03.2013;13:16:46;On; 07.03.2013;13:31:46;On;
07.03.2013;13:46:46;On; 07.03.2013;14:01:46;On; 07.03.2013;14:16:46;On; 07.03.2013;14:31:46;On;
07.03.2013;14:32:48;On; 07.03.2013;14:51:45;On; 07.03.2013;15:01:18;On; 07.03.2013;15:16:17;On;
07.03.2013;15:19:20;On; 07.03.2013;15:28:15;On; 07.03.2013;15:41:50;On; 07.03.2013;15:45:34;On;
07.03.2013;15:52:15;On; 07.03.2013;15:58:18;On; 07.03.2013;16:02:39;On; 07.03.2013;16:02:51;On;
07.03.2013;16:06:56;On; 07.03.2013;16:14:10;On; 07.03.2013;16:21:53;On; 07.03.2013;16:23:19;On;
07.03.2013;16:25:37;On; 11.03.2013;14:15:14;On; 11.03.2013;14:30:13;On; 11.03.2013;14:45:13;On;
11.03.2013;15:00:13;On; 11.03.2013;15:15:13;On; 11.03.2013;15:30:13;On; 11.03.2013;15:45:13;On;
11.03.2013;16:00:13;On; 11.03.2013;16:15:13;On; 11.03.2013;16:30:13;On; 11.03.2013;16:45:13;On;
11.03.2013;17:00:13;On; 11.03.2013;17:15:13;On; 11.03.2013;17:30:13;On; 11.03.2013;17:45:13;On;
11.03.2013;18:00:13;On; 11.03.2013;18:15:13;On; 11.03.2013;18:30:13;On; 11.03.2013;18:45:13;On;
11.03.2013;19:00:13;On; 11.03.2013;19:15:13;On; 11.03.2013;19:30:13;On; 11.03.2013;19:45:13;On;
11.03.2013;20:00:13;On; 11.03.2013;20:15:13;On; 11.03.2013;20:30:13;On; 11.03.2013;20:45:13;On;
11.03.2013;21:00:13;On; 11.03.2013;21:15:13;On; 11.03.2013;21:30:14;On; 11.03.2013;21:45:13;On;
11.03.2013;22:00:13;On; 11.03.2013;22:15:13;On; 11.03.2013;22:30:13;On; 11.03.2013;22:45:13;On;
11.03.2013;23:00:13;On; 11.03.2013;23:15:13;On; 11.03.2013;23:30:13;On; 11.03.2013;23:45:13;On;
12.03.2013;00:00:13;On; 12.03.2013;00:15:13;On; 12.03.2013;00:30:13;On; 12.03.2013;00:45:13;On;
12.03.2013;01:00:13;On; 12.03.2013;01:15:13;On; 12.03.2013;01:30:13;On; 12.03.2013;01:45:13;On;
12.03.2013;02:00:13;On; 12.03.2013;02:15:13;On; 12.03.2013;02:30:13;On; 12.03.2013;02:45:13;On;
12.03.2013;03:00:13;On; 12.03.2013;03:15:13;On; 12.03.2013;03:30:13;On; 12.03.2013;03:45:13;On;
12.03.2013;04:00:13;On; 12.03.2013;04:15:14;On; 12.03.2013;04:30:13;On; 12.03.2013;04:45:13;On;
12.03.2013;05:00:13;On; 12.03.2013;05:15:13;On; 12.03.2013;05:30:13;On; 12.03.2013;05:45:13;On;
12.03.2013;06:00:13;On; 12.03.2013;06:15:13;On; 12.03.2013;06:30:13;On; 12.03.2013;06:45:13;On;
12.03.2013;13:15:55;On; 12.03.2013;13:30:54;On;
    </Data>
  </Download>
  <Result>
    <Success>true</Success>
  </Result>
</Service>

```

Remark:

OZW version V07.00 uses Unix-style line endings with line feed (LF). Earlier OZW versions ≤ V06.00 used Windows style line endings with line feed (LF) and carriage return (CR).

3. Application example for OZW Web API

Following a simple application example to read out the local device list in OZW. The OZW is directly accessed via Ethernet (e.g. a router with explicit port forwarding).

3.1 Authentication: login to OZW

Login to get a new **SessionID** with local OZWx72 credentials

Request:

```
https://192.168.250.1/api/auth/login.json?user=Administrator&pwd=Password.1
```

Response:

```
{
  "SessionId": "c83f5091-17ff-44b4-a62f-ba592ef3ee59",
  "Result":
  {
    "Success": "true"
  }
}
```

3.2 Device list: read list

Query the local device list in OZW

Request:

```
https://192.168.250.1/api/devicelist/list.json?SessionId=c83f5091-17ff-44b4-a62f-ba592ef3ee59
```

Response:

```
{
  "Devices":
  [
    {
      "Name": "OZW772.16",
      "Addr": "0.2.150",
      "Type": "OZW772.16",
      "SerialNr": "00FD00FF0A00",
      "TreeDate": "18.11.2015",
      "TreeTime": "12:49",
      "TreeGenerated": "true"
    },
    ...
  ],
  "Result":
  {
    "Success": "true"
  }
}
```

3.3 Authentication: logout from OZW

Do a logout for the **SessionID**

Request:

```
https://192.168.250.1/api/auth/logout.json?SessionId=c83f5091-17ff-44b4-a62f-ba592ef3ee59
```

Response:

```
{
  "Result":
  {
    "Success": "true"
  }
}
```

4. Use cases for integration via Portal Web API

4.1 Description of use case

In contrast to use case from Section 1.1, the decentralized plants or OZWx72s should now be accessed via the portal.

4.2 Portal Web API: Check version

Checks, based on the services "version", whether this portal Web API version is supported (see 5.4.1 in this document).

4.3 Portal Web API: List of sites

The service "site/list" can query a list of all plants (See Sec. 5.5.2). An individual plant can be identified via a unique OZWx72 device serial number.

- Query all plants with service "site/list"
- Identification of plant via "SerialNr" of OZWx72
- As an option, the service "site/info" can read other detailed plant information (alarm state, connection state, etc.)
- You can access the web server on the OZW with parameter "Uri" (See Sec. 5.5.4).

4.4 OZW Web API: Availability


You can access the (local) web server OZW using parameter "Uri" (e.g. the web API or web pages). When accessing the OZW Web API, consider the same framework conditions are for the direct OZW Web API Application (See Sec. 1).

5. Portal Web API

5.1 General

The Portal Web API is based on the same principles as the OZW Web API. In contrast, the portal Web API provides a cloud-based infrastructure.

All services are offered encrypted HTTPS. The diagram below illustrates how the portal web services is structured:



5.1.1 HTTP response format

The same of OZW Web API (Section 2.1.1).

5.1.2 Interface version /api/...

The same of OZW Web API (Section 2.1.2).

5.1.3 Result

The response is the same in principle as for OZW Web API (Section 2.1.3).

Table of all possible errors on all service groups and services

Error Number		Error													
		0	1	2	3	4	5	6	7	8	9	10	11	12	13
Error Text		unknown error	unknown user or wrong password	session not valid	serial number not found	tree name not valid	tree id not found	read failed	write failed	data type not supported	value not valid	unknown service	unknown format	Serial number or tree name not found	No trend defined or trend version not supported
<ip-addr>/api/															
.../.../	.../version	(X)	-	-	-	-	-	-	-	-	-	-	-	-	-
.../auth/	.../login	-	X	-	-	-	-	-	-	-	-	-	-	-	-
	.../logout	-	-	X	-	-	-	-	-	-	-	-	-	-	-
.../site	.../info	-	-	X	-	-	-	-	-	-	-	-	-	-	-
	.../list	-	-	X	-	-	-	-	-	-	-	-	-	-	-
	.../listextended	-	-	X	-	-	-	-	-	-	-	-	-	-	-
.../unknown/	.../.../	-	-	-	-	-	-	-	-	-	-	X	-	-	
.../.../	.../unknown	-	-	-	-	-	-	-	-	-	-	X	-	-	
.../.../	.../known.unknown	-	-	-	-	-	-	-	-	-	-	-	X	-	


5.1.4 User administration

The port services user administration occurs together with the user administration on the portal (e.g. www.siemens-syncoic.com or www.climatixic.com). The user administration also occurs on to the portal. The entered portal language of a user also defines the languages of data queried via web services.

Authentication occurs the first time on service "login" (see Sec. 5.4.2) and later for other services via the received (portal) SessionId (e.g. SessionId= nXjrw7DY1ikcDhK9vaRwbu). The session is managed together with the portal. A session is not persistent saved on the portal and has a relative timeout of 10 minutes for inactivity.

When using the Portal Web API to call OZW Web API services it is recommended to periodically call the Portal service "site\info" to reset the relative timeout. Alternatively, if only OZW services are used, minimal every 50 seconds a service has to be called.

5.1.5 Overview of web services



5.2 API interface versions

5.2.1 Portal API version 1.0.2

Service group	API	Interface version
API	/api/	1.0.2
Authentication	.../auth/	1.0.2
Site	.../site/	1.0.2

5.3 Common services

Function name	Application
version	Version information of all API services

5.3.1 version - /api/version

Request URI (HTTP GET):

<https://portal/api/version.format>

Request example:

```
http://www.siemens-syncoic.com/api/version.json
```

Response body in JSON:

```
{
  "Version": "1.1.9",
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Version>1.1.9</Version>
  <Result>...</Result>
</Service>
```

5.4 Authentication services

Function name	Application
version	Version information of (portal) authentication service
login	Authentication and resolution of a (portal) SessionID
logout	Concluding a (portal) session

5.4.1 version - /api/auth/version

Request URI (HTTP GET):

<https://portal/api/auth/version.format>

Request example:

```
https://www.siemens-syncoic.com/api/auth/version.json
```

The response content is the same as for service version - /api/version (Sec. 2.3.1).

5.4.2 login - /api/auth/login

Request URI (HTTP GET):

<https://portal/api/auth/login.format>

Example:

```
https://www.siemens-syncoic.com/api/auth/login.json?user=HansMuster&pwd=MyPassword
```

Request parameter:

Parameter	Example	Default value	Description
user	HansMuster@abcd.ch	(none)	(Portal) User name
pwd	MyPassword	(none)	(Portal) Password

Response body in JSON:

```
{
  "SessionId": "nXjrw7DY1ikcDhK9vaRwbu",
  "HasSiteServices"1: "true",
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <SessionId>nXjrw7DY1ikcDhK9vaRwbu</SessionId>
  <HasSiteServices>true</HasSiteServices>1
  <Result>...</Result>
</Service>
```

¹ The parameter “HasSiteServices” indicates whether the portal Web API also offers the service group “site”. The parameter “HasSiteServices” can also be used to distinguish from OZW Web API.

5.4.3 logout - /api/auth/logout

Request URI (HTTP GET):

<https://portal/api/auth/logout.format>

Request example:

```
https://www.siemens-syncoic.com/api/auth/logout.json?SessionId=nXjrw7DY1ikcDhK9vaRwbu
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	nXjrw7DY1ikcDhK9va...	(none)	SessionId of current (portal) session

Response body in JSON:

```
{
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Result>...</Result>
</Service>
```

5.5 Site services

Function name	Application
version	Site services version info
list	List of all sites in the portal ¹
listextended	Extended list of all sites in the portal ¹
info	Info on a site (e.g. Connection Status, URI, etc.)

¹ The list is not sorted

5.5.1 version - /api/site/version

Request URI (HTTP GET):

<https://portal/api/site/version.format>

Request example:

```
https://www.siemens-syncoic.com/api/site/version.json
```

The response content is the same as for service version - /api/version (Sec. 2.3.1).

5.5.2 list - /api/site/list

Request URI (HTTP GET):

<https://portal/api/site/list.format>

Request example:

```
http://www.siemens-syncoic.com/api/site/list.json?SessionId=nXjrw7DY1ikcDhK9vaRwbu
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	nXjrw7DY1ikcDhK9va...	(none)	(Portal) SessionId of the current session

Response body in JSON:

```
{
  "Sites": [
    {
      "Name": "Museum",
      "Description": "Historical museum Zurich",
      "Distributor": "Siemens Proxy",
      "SerialNr": "00FD00FF01F0",
      "Type": "OZW772.16",
      "Uri": "https://www.siemens-syncoic.com/Site/.../web/",
      "SiteId": "b08173af-ead5-e311-b5bf-00a003fd08e8"
    },
    {
      "Name": "Museum",
      "Description": "Natural museum Lucerne",
      "Distributor": "Siemens Proxy",
      "SerialNr": "00FD00FF033A",
      "Type": "OZW672.16",
      "Uri": "https://www.siemens-syncoic.com/Site/.../web/",
      "SiteId": "64aa9cec-caad-e311-baaf-00a003fd51d8"
    }
  ],
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Sites>
    <Site>
      <Name>Museum</Name>
      <Description>Historical museum Zurich</Description>
      <Distributor>Siemens Proxy</Distributor>
      <SerialNr>00FD00FF01F0</SerialNr>
      <Type>OZW772.16</Type>
      <Uri>https://www.siemens-syncoic.com/Site/.../web/</Uri>2
      <SiteId>b08173af-ead5-e311-b5bf-00a003fd08e8</SiteId>1
    </Site>
    <Site>
      <Name>Museum</Name>
      <Description>Natural museum Lucerne</Description>
      <Distributor>Siemens Proxy</Distributor>
      <SerialNr>00FD00FF033A</SerialNr>
      <Type>OZW672.16</Type>
      <Uri>https://www.siemens-syncoic.com/Site/.../web/</Uri>2
      <SiteId>64aa9cec-caad-e311-baaf-00a003fd51d8</SiteId>1
    </Site>
  </Sites>
  <Result>...</Result>
</Service>
```

¹ A site can be clearly identified based on parameter "SerialNr".

² You can access the (local) web server on the OZW via the portal with parameter "Uri" (e.g. of Web API). When accessing via the portal, the (portal) SessionID as parameter must always be provided).

5.5.3 listextended - /api/site/listextended

Request URI (HTTP GET):

<https://portal/api/site/listextended.format>

Request example:

`http://www.siemens-syncoic.com/api/site/listextended.json?SessionId=nXjrw7DY1ikcDhK9vaRwbu`

Request parameter:

Parameter	Example	Default value	Description
SessionId	nXjrw7DY1ikcDhK9va...	(none)	(Portal) SessionId of the current session

Response body in JSON:

```
{
  "Sites": [
    {
      "TenantId": "0346c600-8ad0-4b30-914d-7dd3fcfee610",
      "Address": "Abbay Road",
      "City": "London",
      "Country": "England",
      "State": "England",
      "ZipCode": "EC2R 6AB",
      "AccessCode": "5afbddd1-f79a-4e78-82c3-25da2a563454",
      "Connection": true,
      "Alarm": true,
      "Rta": false,
      "Name": "Museum",
      "Description": "Historical museum",
      "Distributor": "Siemens Proxy",
      "SerialNr": "00FD00FF01F0",
      "Type": "OZW772.16",
      "Uri": "https://www.siemens-syncoic.com/Site/.../web/",
      "SiteId": "b08173af-ead5-e311-b5bf-00a003fd08e8"
    },
    {
      "TenantId": "0346c600-8ad0-4b30-914d-7dd3fcfee610",
      "Address": "Abbay Road",
      "City": "London",
      "Country": "England",
      "State": "England",
      "ZipCode": "EC2R 6AB",
      "AccessCode": "285379e6-be03-46a0-8ed0-b745d323e36b",
      "Connection": true,
      "Alarm": true,
      "Rta": false,
      "Name": "Museum",
      "Description": "Natural museum",
      "Distributor": "Siemens Proxy",
      "SerialNr": "00FD00FF033A",
      "Type": "OZW672.16",
      "Uri": "https://www.siemens-syncoic.com/Site/.../web/",
      "SiteId": "64aa9cec-caad-e311-baaf-00a003fd51d8"
    }
  ],
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Sites>
    <Site>
      <TenantId>0346c600-8ad0-4b30-914d-7dd3fcfee610</TenantId>
      <Address>Abbay Road</Address>
      <City>London</City>
      <Country>England</Country>
      <State>England</State>
      <ZipCode>EC2R 6AB</ZipCode>
      <AccessCode>5afbdda1-f79a-4e78-82c3-25da2a563454</AccessCode>
      <Connection>true</Connection>
      <Alarm>true</Alarm>
      <Rta>>false</Rta>
      <Name>Museum</Name>
      <Description>Historical museum</Description>
      <Distributor>Siemens Proxy</Distributor>
      <SerialNr>00FD00FF01F0</SerialNr>
      <Type>OZW772.16</Type>
      <Uri>https://www.siemens-syncoic.com/Site/.../web/</Uri>2
      <SiteId>b08173af-ead5-e311-b5bf-00a003fd08e8</SiteId>1
    </Site>
    <Site>
      <TenantId>0346c600-8ad0-4b30-914d-7dd3fcfee610</TenantId>
      <Address>Abbay Road</Address>
      <City>London</City>
      <Country>England</Country>
      <State>England</State>
      <ZipCode>EC2R 6AB</ZipCode>
      <AccessCode>285379e6-be03-46a0-8ed0-b745d323e36b </AccessCode>
      <Connection>true</Connection>
      <Alarm>>false</Alarm>
      <Rta>>true</Rta>
      <Name>Museum</Name>
      <Description>Natural museum</Description>
      <Distributor>Siemens Proxy</Distributor>
      <SerialNr>00FD00FF033A</SerialNr>
      <Type>OZW672.16</Type>
      <Uri>https://www.siemens-syncoic.com/Site/.../web/</Uri>2
      <SiteId>64aa9cec-caad-e311-baaf-00a003fd51d8</SiteId>1 </Site>
    </Sites>
  </Result>...</Result>
</Service>
```

¹ A site can be clearly identified based on parameter “SerialNr”.

² You can access the (local) web server on the OZW via the portal with parameter “Uri” (e.g. of Web API). When accessing via the portal, the (portal) SessionID as parameter must always be provided).

5.5.4 info - /api/site/info

Request URI (HTTP GET):
<https://portal/api/site/info.format>

Request Example:

```
http://www.siemens-syncoic.com/api/site/info.json?SessionId=nXjrw7DY1ikcDhK9vaRwbu
&SerialNr=00FD00FF033A&Type=OZW672.16&Distributor=Siemens%20Proxy
```

Request parameter:

Parameter	Example	Default value	Description
SessionId	nXjrw7DY1ikcDhK9va...	(none)	(Portal) SessionId of the current session
SerialNr	00FD00FF033A	(none)	Device serial number
Type	OZW672.16	(none)	ASN
Distributor	Siemens Proxy	(none)	Distributor

Response body in JSON:

```
{
  "Uri": "https://www.siemens-syncoic.com/Site/.../web/",
  "Connection": true1,
  "Alarm": true,
  "Result": ...
}
```

Response body in XML:

```
<Service>
  <Uri>"https://www.siemens-syncoic.com/Site/.../web/"</Uri>
  <Connection>true</Connection>
  <Alarm>true</Alarm>1
  <Result>...</Result>
</Service>
```

¹ The parameter "Connection" indicate the connection state to site ("true" = connected, "false" = disconnected)

² The (local) web server can access the OZW via the portal using parameter "Uri" (e.g. to Web API). When accessing via portal, the (portal) SessionID must always be provided as parameter.

6. Application example for Portal and OZW Web API

Following a simple application example to read out the local device list in OZW. The OZW is connected to Climatix IC / Synco IC.

6.1 Authentication: login to Climatix / Synco IC

Login to get a new **cloud SessionID** (with Climatix IC / Synco IC credentials)

Request:

```
https://www.climatixic.com/api/auth/login.json?user=name@company.com&pwd=Password.1
```

Response:

```
{
  "SessionId": "HvwuXtmm-U6yxbobQFCpwg",
  "HasSiteService": true,
  "Result":
  {
    "Success": true
  }
}
```

6.2 Site: list of sites

Query the list of available sites in Climatix IC / Synco IC and the correspondings **site-specific URIs**

Request:

```
https://www.climatixic.com/api/site/list.json?SessionId=HvwuXtmm-U6yxbobQFCpwg
```

Response:

```
{
  "Sites":
  [
    {
      "Name": "Site name in Cloud",
      "Description": "",
      "Distributor": "Siemens Proxy",
      "SerialNr": "00FD00FEFE01",
      "Type": "OZW672.16",
      "Uri": "https://www.climatixic.com/Site/RemoteWeb/8cce4498-1013-46f9-ala2-847406cc6280/web/",
      "SiteId": "d0472ab7-9adb-e311-b3e6-00a003fd1713"
    },
    ...
  ],
}
```

6.3 Device list: read list

Query the local OZW device list via Climatix IC / Synco IC.

Request:

```
https://www.climatixic.com/Site/RemoteWeb/8cce4498-1013-46f9-ala2-847406cc6280/web/api/devicelist/list.json?SessionId=HvwuXtmm-U6yxbobQFCpwg
```

Response:

```
{
  "Devices":
  [
    {
      "Name": "OZW772.16",
      "Addr": "0.2.150",
    }
  ]
}
```

```
        "Type": "OZW772.16",
        "SerialNr": "00FD00FF0A00",
        "TreeDate": "18.11.2015",
        "TreeTime": "12:49",
        "TreeGenerated": "true"
      }
    ],
    "Result":
    {
      "Success": "true"
    }
  }
}
```

6.4 Authentication: logout from Climatix / Synco IC

Do a logout for the **cloud SessionID**

Request:

```
https://www.climatixic.com/api/auth/logout.json?SessionId=hvwuXtmm-U6yxbobQFCpwg
```

Response:

```
{
  "Result":
  {
    "Success": "true"
  }
}
```